

April 9, 2024

PROJECT NAME: MINOR SITE PLAN FOR DAN WILSON

PROJECT NUMBER: 2023110014

APPLICATION: MINOR SITE PLAN #30825

1 DEPARTMENT: ENRAA - ACQ AGENT ENG ROW

REVIEW ITEM: Minor Site Plan

STATUS OF REVIEW: INFO

REMARKS: IF APPLICABLE:

Sec. 2.18.1.I - Show connections to other phases.

Sec.2.19.2.H – Legal Documents

Legal documents such as Declaration of Covenants and Restrictions, By-Laws, Articles of Incorporation, ordinances, resolutions, etc.

Sec. 6.3.1.B.1 – Required Right of Way Dedication (select as appropriate)

For Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated for the use and benefit of the public."

Sec. 6.3.1.B.2 – Required Right of Way Dedication

For Non-Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated privately to the [entity name]. All public authorities and their personnel providing services to the subdivision are granted an easement for access. The Board of County Commissioners of Marion County, Florida, shall have no responsibility, duty, or liability whatsoever regarding such streets. Marion County is granted an easement for emergency maintenance in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."

Sec. 6.3.1.D.3 - Cross Access Easements

For Cross Access Easements. "All parallel access easements shown on this plat are hereby dedicated for the use and benefit of the public, and maintenance of said easements is the responsibility of [entity name]."

Sec. 6.3.1.C.1 - Utility Easements (select as appropriate)

"[All utility easements shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction, installation, maintenance, and operation of utilities by any utility provider."

Sec. 6.3.1.C.2 – Utility Easements

"[All utility tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."

Sec.6.3.1.D(c)(1)(2)(3) - Stormwater easements and facilities, select as appropriate:

1 "[All stormwater and drainage easements as shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction and maintenance of such facilities."

2. "[All stormwater management tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."

3. When any stormwater easement and/or management tract is not dedicated to the public or Marion County directly, the following statement shall be added to the dedication language: "Marion County is granted the right to perform emergency maintenance on the [stormwater easement and/or management tract, complete accordingly] in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."

Sec.6.3.1.D(f) –

If a Conservation Easement is required the following shall be provided: "A conservation easement [as shown or on tract and identify the tract, complete accordingly] is dedicated to [the Board of County Commissioners of Marion County, Florida or entity name, if not Marion County] for the purpose of preservation of [listed species, habitat, Karst feature and/or native vegetation, complete accordingly]."

- 2 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 2.12.4.L(6) - Gross/wetland/floodplain acreage listed?
STATUS OF REVIEW: INFO
REMARKS: No wetland or floodplain areas.
- 3 DEPARTMENT: DOH - ENVIRONMENTAL HEALTH
REVIEW ITEM: DEP Water Approval
STATUS OF REVIEW: INFO
REMARKS: Well will require permit through Florida Department of Environmental Protection or Department of Health in Marion County. Number of employees and visitors per day will determine.
- 4 DEPARTMENT: DOH - ENVIRONMENTAL HEALTH
REVIEW ITEM: Additional Health comments
STATUS OF REVIEW: INFO
REMARKS: Septic permit will be required through the Department of Health in Marion County.
- 5 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: 2.20.1.A - When any of the Minor Site Plan thresholds are exceeded, a Major Site Plan is required
STATUS OF REVIEW: INFO
REMARKS:
- 6 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: 4.4.4 - Sign (provisions for advertising signage), if it is a multi occupancy complex like shopping centers they must submit a master sign plan.
STATUS OF REVIEW: INFO
REMARKS: Will there be any signs? Provide location and dimensions of all proposed signs.
- 7 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: 2.12.27 - Show location of outside storage areas
STATUS OF REVIEW: INFO
REMARKS: will there be outside storage?
- 8 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: 2.12.32 - Show 100yr flood zone
STATUS OF REVIEW: NO
REMARKS: provide flood zone
- 9 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: 2.12.32 - Modified environmental assessment or exemption if information is available to the county to indicate no habitat or existence of endangered species or vegetation (Article 6, Division 5, Sec. 6.5.4)
STATUS OF REVIEW: NO
REMARKS: provide environmental assessment or exemption.
- 10 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: 5.2 & 5.3 - Verify any overlay zones such as ESOZ, Springs Protection, or Flood Plain
STATUS OF REVIEW: NO
REMARKS: Provide springs protection zone (secondary).

- 11 DEPARTMENT: FRMSH - FIRE MARSHAL REVIEW
REVIEW ITEM: 6.18.2 - Fire Flow/Fire Hydrant
STATUS OF REVIEW: NO
REMARKS: Site Plan will need to show fire department water supply within 400 feet of the building.
- 12 DEPARTMENT: ENGTRF - TRAFFIC REVIEW
REVIEW ITEM: 6.11.3 - Traffic Impact Analysis
STATUS OF REVIEW: NO
REMARKS: 11/19/23 - Provide a traffic statement on the cover sheet.
- 13 DEPARTMENT: ENGTRF - TRAFFIC REVIEW
REVIEW ITEM: 6.11.4.B - Cross access
STATUS OF REVIEW: NO
REMARKS: 11/19/23 - A 24' wide paved cross access easement is required along NW Gainesville Road. Show the easement on the plans and pave it to the southern property line. The easement shall be recorded prior to final plan approval. Please contact Cheryl Weaver in the right-of-way office for the required standard easement template and to coordinate the recording of the easement.
- 14 DEPARTMENT: ENGTRF - TRAFFIC REVIEW
REVIEW ITEM: 6.11.5 - Driveway access
STATUS OF REVIEW: NO
REMARKS: 11/19/23 - The driveway needs to be located next to the western property line to maximize spacing from NW Gainesville Road.
- 15 DEPARTMENT: ENGTRF - TRAFFIC REVIEW
REVIEW ITEM: 6.11.9.C - Pavement marking
STATUS OF REVIEW: NO
REMARKS: 11/19/23 - Show the width of the parking spacings and the length and width of the handicap aisle.
- 16 DEPARTMENT: ENGTRF - TRAFFIC REVIEW
REVIEW ITEM: 6.12.2 - Right-of-way
STATUS OF REVIEW: NO
REMARKS: 11/19/23 - The right-of-way on NW Gainesville Road does not meet current standards. A right-of-way dedication of 27 feet is required.
- 17 DEPARTMENT: ENGTRF - TRAFFIC REVIEW
REVIEW ITEM: 6.12.12 - Sidewalks
STATUS OF REVIEW: NO
REMARKS: 11/19/23 - 1. Sidewalk is required along NW Gainesville Road with access onto the site. 2. An accessible route needs to be provided from the handicap spot to the building entrance including sidewalk.
- 18 DEPARTMENT: 911 - 911 MANAGEMENT
REVIEW ITEM: Additional 911 comments
STATUS OF REVIEW: NO
REMARKS: Sheet 02 has incorrect Project Address of 8985 NW County Rd 25A listed in Site Data. It should be TBD.
- 19 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.7.3 - Tree protection
STATUS OF REVIEW: NO
REMARKS: Show tree protection on plan and in detail

- 20 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.8.6 - Buffers
STATUS OF REVIEW: NO
REMARKS: 1. Show overhead power on plan. 2. North buffer does not meet requirements for ornamental trees; shrubs and groundcovers are too sparse, does not meet 50% requirement. 3. East buffer - see comment for north buffer. 4. Show south and west buffers, Type D . 5. Pine straw mulch is not recommended, breaks down to quickly. Consider mini pine bark nuggets.
- 21 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.8.7 - Parking areas and vehicular use areas
STATUS OF REVIEW: NO
REMARKS: 1.Shade trees are required at each terminus island, or at the ends on the parking area. 2. Min 5' strip of screening material required around the perimeter of the parking area
- 22 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.8.8 - Building landscaping
STATUS OF REVIEW: NO
REMARKS: 1. Min. 5' strip of screening material along 60% of the public view side of building, in this case along the north and east sides
- 23 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.8.9 - Service and equipment areas
STATUS OF REVIEW: NO
REMARKS: Will there be a dumpster? if so, show screening
- 24 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.13.3 D(4) - Landscaping of private stormwater management facilities
STATUS OF REVIEW: NO
REMARKS: Will there be a Stormwater Retention Area? If so, additional screening may be required
- 25 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.8.10 - General planting requirements (specifications)
STATUS OF REVIEW: NO
REMARKS: Provide plant spacing details
- 26 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.9.2 - Irrigation plan requirements (details, legend, notes)
STATUS OF REVIEW: NO
REMARKS: Show water source, controller and rain sensor locations
- 27 DEPARTMENT: LSCAPE - LANDSCAPE DESIGN AND IRRIGATION
REVIEW ITEM: 6.19.3 - Outdoor lighting plan requirements
STATUS OF REVIEW: NO
REMARKS: Will there be outdoor lighting? if so, a photometric plan is required
- 28 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 2.12.4.L(5)/5.2 - [Applicable ESOZ/FPOZ Status Listed?]
STATUS OF REVIEW: NO
REMARKS: Please provide whether or not this is in ESOZ area.

- 29 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 2.12.4.L(5)/5.4 - [Applicable Springs Protection Zone Listed?]
STATUS OF REVIEW: NO
REMARKS: What Springs protection zone is this in?
- 30 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 2.12.4.L(5)/5.7 - Wellhead Protection - P/S/T Zones Shown/Listed?
STATUS OF REVIEW: NO
REMARKS: Please provide wellhead protection zone.
- 31 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 2.12.16/6.5 - [EALS or EALS-ER provided?]
STATUS OF REVIEW: NO
REMARKS: Environmental assessment must be provided.
- 32 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 6.5 & 6.6 - Habitat Preservation/Mitigation Provided?
STATUS OF REVIEW: NO
REMARKS: If listed species present, mitigation plan to be provided.
- 33 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: 2.12.5/1.8.2.F - Is Concurrency Approval or Deferral Elected?
STATUS OF REVIEW: NO
REMARKS: Concurrency approval or deferral must be elected.
- 34 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: Additional Planning Items:
STATUS OF REVIEW: NO
REMARKS: This site plan exceeds the threshold for a minor site plan and should be a major site plan review.



**Marion County
Board of County Commissioners**

AR 30825

Office of the County Engineer

412 SE 25th Ave.
Ocala, FL 34471
Phone: 352-671-8686
Fax: 352-671-8687

DEVELOPMENT REVIEW COMMITTEE WAIVER REQUEST FORM

Date: 4/8/2024 Parcel Number(s): 12869-000-00 Permit Number: _____
mm/dd/yyyy

A. PROJECT INFORMATION: Fill in below as applicable:

Project Name: Minor Site Plan for Dan Wiilson Commercial or Residential
Subdivision Name (if applicable): N/A
Unit _____ Block _____ Lot _____

B. PROPERTY OWNER'S AUTHORIZATION: Attach a letter from the owner(s) or the owner(s) may sign below authorizing the applicant to act on the owner's behalf for this waiver request:

Property Owner's Name (print): Dan Wilson
Property Owner's Signature: _____
Property Owner's Mailing Address: 8985 NW CR 25A
City: Ocala State: FL Zip Code: 34475 Phone # 352-572-2094

C. APPLICANT INFORMATION: The applicant will be the point of contact during this waiver process and will receive correspondence.

Firm Name (if applicable): Abshier Engineering Inc. Contact Name: Ed Abshier
Mailing Address: P.O. Box 2770 City: Belleview State: FL Zip Code: 34421
Phone # 352-266-9555 Alternate Phone # 352-245-8592
Email address: ed@abshiereng.com

D. WAIVER INFORMATION:

Section & Title of Code: 6.8.6 - Buffers South & West
Reason/Justification for Waiver Request: The Parcel to the West and South are undeveloped.
The FLU is runoff on site is commerce district. It will be developed as commercial in the future.
No buffer should be required.

DEVELOPMENT REVIEW USE:

Received By: Email 4/9/24 Date Processed: 4/9/24 BM Project # 2023110014 AR # 30825

ZONING USE: Parcel of record: Yes No Eligible to apply for Family Division: Yes No
Zoned: _____ ESOZ: _____ P.O.M. _____ Must Vacate Plat: Yes No
Land Use: _____ Date: _____ Verified by: _____

Revised 7/2017


Marion County Florida - Interactive Map



11/8/2023, 8:11:13 AM

- Marion County
- Parcels
- County Road Maintenance
- OCE Maintained Paved
- Not Maintained
- Streets
- Green: Band_2
- Blue: Band_3
- Red: Band_1

1:4,514



Marion County Property Appraiser, Esri Community Maps Contributors, Marion County Property Appraiser, FDEP, © OpenStreetMap, Microsoft, Esri, HERE, Garmin, SafeGraph, GeoTechnologies, Inc, METI/NASA, USGS, EPA, NPS, US Census Bureau, USDA, OCE, Marion


Marion County Board of County Commissioners

This map is provided "as is" without any warranty or representation of accuracy, timeliness, completeness, merchantability, or fitness. The user is responsible for verifying any information and assumes all risk for reliance on any information herein.

MINOR SITE PLAN

FOR

DAN WILSON



DESCRIPTION:

(PER OFFICIAL RECORDS BOOK 3362, PAGE 240, PUBLIC RECORDS OF MARION COUNTY, FLORIDA)
 COMMENCING AT THE NW CORNER OF SECTION 14, TOWNSHIP 14 SOUTH, RANGE 21 EAST, MARION COUNTY, FLORIDA, THENCE S.02°39'18"W, ALONG THE WEST BOUNDARY OF SAID SECTION 14 A DISTANCE OF 235.08 FEET TO AN INTERSECTION WITH THE SOUTH RIGHT OF WAY LINE OF N.W. 89TH PLACE (FRESSDEN SCHOOL ROAD) (100 FEET WIDE) AND THE POINT OF BEGINNING THENCE N.86°25'20"E, ALONG SAID SOUTH RIGHT OF WAY LINE 167.65 FEET TO AN INTERSECTION WITH THE WESTERLY RIGHT OF WAY LINE OF NW GARDENVILLE ROAD (OLD U.S. 441) (66 FEET WIDE), SAID POINT BEING ON A NON-TANGENT CURVE TO THE WEST AND HAVING A RADIUS OF 6696.70 FEET; THENCE SOUTHERLY ALONG AND WITH THE ARC OF SAID RIGHT OF WAY CURVE THROUGH A CENTRAL ANGLE OF 01°12'47", AN ARC DISTANCE OF 120.61 FEET AND SUBTENDED BY A CHORD BEARING AND DISTANCE OF S.17°40'09"E, 120.60 FEET TO THE POINT OF TANGENCY; THENCE S.13°23'42"E, ALONG SAID WESTERLY RIGHT OF WAY LINE 107.07 FEET; THENCE DEPARTING FROM SAID WESTERLY RIGHT OF WAY LINE S.89°25'30"W, 222.93 FEET TO AN INTERSECTION WITH SAID WEST BOUNDARY OF SECTION 14; THENCE N.00°39'18"E, ALONG SAID WEST BOUNDARY 223.02 FEET TO THE POINT OF BEGINNING.



VICINITY MAP

INDEX OF SHEETS

- 1. COVER SHEET
- 2. SITE PLAN
- 3. STORM DRAINAGE & UTILITY PLAN
- L1. LANDSCAPE PLAN
- L2. LANDSCAPE DETAILS

ENGINEERS CERTIFICATE

I HEREBY CERTIFY THAT THESE PLANS AND CALCULATIONS WERE COMPLETED IN ACCORDANCE WITH ALL APPLICABLE REQUIREMENTS OF THE MARION COUNTY LAND DEVELOPMENT CODE (LDC), EXCEPT AS WAIVED.



EDWARD ABSHER, JR.
 FLORIDA REGISTERED ENGINEER NO. 53961


OWNER'S SIGNATURE

I HEREBY CERTIFY THAT I, MY SUCCESSORS, AND ASSIGNS SHALL PERPETUALLY MAINTAIN THE IMPROVEMENTS AS SHOWN ON THIS PLAN.

DAN WILSON

OWNERS/DEVELOPER
 DAN WILSON
 8985 NW COUNTY ROAD 25A
 OCALA, FL 34475
 (352) 572-2094

ABSHIER ENGINEERING, INC.
 5614 SE 111th STREET, BELLEVUE, FLORIDA
 P.O. BOX 2770 CA# 9930 PHONE: (352) 245-8592
 BELLEVUE, FL 34421-2770 FAX: (352) 245-8597



SITE DATA

1. TOTAL ACRES = 43.624sf
2. ZONING = B-4, LAND USE = CD
3. PROJECT ADDRESS - 8985 NW COUNTY ROAD 25A
4. BUILDING TYPE - STEEL
5. BUILDING HEIGHT - 20'
6. STANDARD PARKING SPACES: PROVIDED = 7 SPACES, REQUIRED = 3 SPACES
7. HANDICAP PARKING SPACES: PROVIDED = 1 SPACE, REQUIRED = 1 SPACE
8. OWNER/DEVELOPER - DAN WILSON, 8985 NW COUNTY ROAD 25A, Ocala, FL 34475, (352) 572-2094
9. ENGINEER - ABSHER ENGINEERING, INC., P.O. BOX 2770, BELLEVILLE, FL 34421-2770, (352) 242-8592
10. SOIL TYPE - KENDRICK
11. PERMITTING AGENCIES - MARION COUNTY
12. WATER BY WELL, SEWER BY SEPTIC
13. ELECTRICAL, TRANSMISSION SYSTEM PROVIDED BY STATE EMPLOY
14. LOCATED IN SECTION 14, TOWNSHIP 14 SOUTH, RANGE 21 EAST, MARION COUNTY, FLORIDA
15. PROPOSED BUILDING AREA = 4,800sf
16. PROPOSED OTHER IMPERVIOUS AREA = 4,853sf
17. TOTAL IMPERVIOUS AREA = 9,653sf (22.1%)
18. OPEN AREA = 33,971sf (77.9%)
19. FLOOR AREA RATIO = 0.28
20. INTENDED USE FOR SITE = WAREHOUSE

NOTES:

1. ALL RADII ARE 4' UNLESS OTHERWISE NOTED.
2. ALL RADII SHOWN ARE TO EDGE OF PAVEMENT.
3. ALL PARKING LOT STRIPING TO BE 4" PAINT.
4. IF COACHING, WARNING, HANDICAP SIGN MAY BE MOUNTED ON BUILDING.
5. NO PARKING LOT LIGHTS ARE PROPOSED IF PARKING LOT LIGHTS ARE ADDED IN THE FUTURE, THEY SHALL MEET THE REQUIREMENTS OF SECTION 6.19 OF THE MARION COUNTY LAND DEVELOPMENT CODE.
6. ALL TRAFFIC CONTROL SIGNS TO BE 84" ABOVE GRADE AT BOTTOM OF SIGN.

"HOLDS FAMILY REVOCABLE TRUST"
PARCEL NO. 12869-000-00
ZONED - A-1
FILE - CD

"HOLDS FAMILY REVOCABLE TRUST"
PARCEL NO. 12901-000-00
ZONED - A-1
FILE - CD

DESCRIPTION:
(PER OFFICIAL RECORDS BOOK 3362, PAGE 240, PUBLIC RECORDS OF MARION COUNTY, FLORIDA)
COMMENCING AT THE NW CORNER OF SECTION 14, TOWNSHIP 14 SOUTH, RANGE 21 EAST, MARION COUNTY, FLORIDA, THENCE S.02°39'14"W, ALONG THE WEST BOUNDARY OF SAID SECTION 14 A DISTANCE OF 233.08 FEET TO AN INTERSECTION WITH THE SOUTH RIGHT OF WAY LINE OF N.W. 89TH PLACE (FEESSENDEN SCHOOL ROAD) (100 FEET WIDE) AND THE POINT OF BEGINNING, THENCE N.88°22'35"E, ALONG SAID SOUTH RIGHT OF WAY LINE 147.65 FEET TO AN INTERSECTION WITH THE WESTERLY RIGHT OF WAY LINE OF NW GAINESVILLE ROAD (OLD U.S. 441) (66 FEET WIDE) SAID POINT BEING ON A NON-TANGENT CURVE TO THE WEST AND HAVING A RADIUS OF 5466.70 FEET; THENCE SOUTHERLY ALONG AND WITH THE ARC OF SAID RIGHT OF WAY CURVE THROUGH A CENTRAL ANGLE OF 0°11'24", AN ARC DISTANCE OF 120.61 FEET AND SUBTENDED BY A CHORD BEARING AND DISTANCE OF S.13°40'09"E, 120.60 FEET TO THE POINT OF TANGENCY, THENCE S.13°03'45"E, ALONG SAID WESTERLY RIGHT OF WAY LINE 107.27 FEET; THENCE DEPARTING FROM SAID WESTERLY RIGHT OF WAY LINE S.88°22'35"W, 222.82 FEET TO AN INTERSECTION WITH SAID WEST BOUNDARY OF SECTION 14; THENCE N.02°39'16"E, ALONG SAID WEST BOUNDARY 223.02 FEET TO THE POINT OF BEGINNING.

THIS DOCUMENT IS PREPARED BY ABSHER ENGINEERING, INC. FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. IT IS NOT TO BE USED FOR ANY OTHER PROJECT OR SITE WITHOUT THE WRITTEN PERMISSION OF ABSHER ENGINEERING, INC.

REVISIONS NO. DATE BY _____ _____ _____	DATE: 10/12/23 DRAWN BY: D.E.P. CHECK BY: D.E.P.
---	--

ABSHER ENGINEERING, INC.
SCALE: 1/8" = 1'-0" (VERTICAL)
SCALE: 1/4" = 1'-0" (HORIZONTAL)
P.O. BOX 2770 BELLEVILLE, FL 34421-2770
PHONE: (352) 242-8592 FAX: (352) 242-8597

SITE PLAN
MINOR SITE PLAN
DAN WILSON
MARION COUNTY, FLORIDA

DATE: 10/12/23
DRAWN BY: D.E.P.
CHECK BY: D.E.P.

EWARD RESKIE, P.E., RESR10
DATE: November 09, 2023

SHT. 2 OF 2

