
1 **Sec. 6.13.9. Grading criteria.**

2 A. Parcels and lots with a County approved individual lot grading plan or part of a multi-lot grading plan. The
3 intent is to demonstrate that Sufficient-sufficient grading shall be designedis provided to allow surface water
4 runoff and controlled discharge to be drained to the retention/detentionapproved drainage areas without
5 causing adverse ~~affects-effects on-to~~ adjacent property. Each parcel or lot shall have a direct connection to
6 the stormwater system; unless the applicant can clearly demonstrate that there are not adverse impacts to
7 adjacent property. In subdivisions, each lot shall have grading designed to be independent of any other lot
8 unless provisions are made for multi-lot grading at initial phase of development; and/or easements for
9 grading purposes are established. All downstream grading must be at a level of completion to support
10 upstream development prior to or simultaneously with the upstream development. Lot Grading-grading
11 plans can-shall be prepared by a qualified Florida licensed professional and may be demonstrated by the use
12 of flow arrows, spot grades, and other iteration callouts, details, and typical grading depictions, or any
13 combination thereof.

14 B. Parcels and lots without a County approved lot grading plan. The intent is to demonstrate that sufficient
15 grading is provided to establish stable slopes and to allow surface water runoff and controlled discharge to
16 be drained without causing adverse effects to adjacent property. Grading may be demonstrated by the use
17 of flow arrows, spot grades, and other iteration callouts, details, and typical grading depictions, or any
18 combination thereof. Unless alternate grading criteria is provided by a lot grading plan, parcels and lots equal
19 to or less than 75 feet in width shall comply with the following grading criteria in addition to all other grading
20 requirements as confirmed by a pre and post development lot grade survey prepared by a Florida licensed
21 Professional Surveyor:

22 1. Fill shall be limited to the under-roof area of the lot's primary structure, access driveway footprint, and
23 respective tapers to existing grade;

24 2. The finished floor elevation of the structure shall not exceed 32 inches above lowest existing adjacent lot
25 line elevation unless vertical walls such as stem walls or retaining walls are used to tie into existing grade;

26 3. The driveway grade shall be no greater than 20% and shall not exceed 10% for a distance of 10 feet from
27 the edge of roadway or shoulder unless a 9-foot minimum vertical curve is provided;

28 4. There shall be no net change to the average elevation of the existing grade of the lot outside of the under-
29 roof area of the lot's primary structure or access driveway footprint and respective taper. Small changes in
30 grade of up to 6 inches is permitted for the purposes of smoothing and evening grade; and

31 5. Fill shall not encroach into the required side or rear lot setbacks except for the taper out from the slab or
32 access driveway to existing grade provided that an equal volume is removed and a swale is formed. Swale
33 shall be capable of directing surface water runoff without causing adverse effects to adjacent property and
34 shall be sloped at a minimum of 2% if located within 10 feet of the building foundation.

35 ~~BC.~~ Buildings. All buildings shall have a minimum finished floor elevation 8 inches above finish grade and graded
36 away from the building for stormwater runoff. Exception: porches, patios, carports, garages, screen rooms
37 may be 4 inches above finish grade.

38 D. Elevations above base flood. In no case shall finished-Finished floor elevations for all buildings except
39 manufactured homes shall be specified below the 12 inches at minimum above the subject property's base
40 flood elevation (BFE).one percent (100-year) flood plain plus one foot. Manufactured homes shall comply
41 with the requirements of Chapter 15C-1, F.A.C. and Sec. 5.3.12. - Manufactured homes. The BFE shall be
42 established by the following most current and best available information:

43 1. The subject property's current applicable FEMA Flood Insurance Rate Map (FIRM) Panel flood elevation;

44 2. FEMA approved Letter of Map Change (LOMC);

45 3. County determined flood prone area as established by a County watershed management plan when the
46 subject property lies within a flood prone area with identified flood elevations and either no FIRM flood
47 elevation has been established or the FIRM flood elevation is lower than the flood prone area flood
48 elevation;

49 4. Historic FEMA LOMC or FIRM Panel flood elevation applicable to the subject property as determined by
50 the County Flood Plain Administrator or their designee;

51 5. Other flood elevation data prepared in accordance with currently accepted engineering practices supplied
52 by the applicant that has been reviewed and approved by the County Engineer or their designee and deemed
53 acceptable by the Floodplain Administrator or their designee; or

54 6. No less than 2 feet above Highest Adjacent Grade when BFE is unavailable from all other sources and the
55 available data are deemed by the Floodplain Administrator or their designee to not reasonably reflect
56 flooded conditions or where the available data are known to be scientifically or technically incorrect or
57 otherwise inadequate, provided that there is no evidence indicating flood depths have been or may be
58 greater than 2 feet.

59 Under no circumstance shall a building permit be issued based on a lower BFE proposed by a LOMC request
60 until the revision has been issued by FEMA.

61 **CE.** Driveways. In the case where roadside swales are the drainage conveyance system, driveway design
62 information shall be included on the plans minimally addressing culvert type, size, invert elevation, and
63 direction of slope of culvert or the placement of ditch block for each at every specific lot. If design is not to
64 be lot-specific, design shall be based on worst-case scenario.

65 **DE.** Affidavit. At time of building application, applicant shall provide an affidavit that the impervious area, lot
66 grading plan, minimum finished floor elevation, and stormwater system complies with the development plan
67 on file with the County. If no development plan is on file, applicant shall provide an affidavit that all drainage
68 is held on-site or directly ~~is~~ connected to a recognized drainage system and that the lot grading complies
69 with the requirements of this section of code. If located within a FEMA Special Flood Hazard Area (SFHA) or
70 flood prone area, the affidavit must also indicate that the lot grading complies with the requirements of Sec.
71 6.13.5. - Floodplain storage and conveyance protection. The applicant shall provide a sketch with the building
72 application indicating the drainage intent.

73 **EG.** Construction. All stormwater runoff ~~increase~~ increases during construction and following ~~must~~ shall be kept
74 on-site or directed to swales, ditches, or piping to approved drainage areas with adequate permitted
75 capacity. Drainage area capacity shall be determined to be adequate by approved development lot
76 impervious ground coverage or approved impervious coverage resulting in additional excess stormwater
77 runoff as accounted by the development's stormwater analysis. If no impervious lot area accounting or
78 stormwater analysis exists for a development, FEMA FIRM or flood prone data may be used to determine
79 adequate drainage area capacity.