Development Review Comments Letter

JULIETTE FALLS TEMP PRO-SHOP ZO SUP #32731

ID	DESCRIPTION	REMARK	STATUS	DEPT
1	Special Use Permit	N/A	INFO	911
2	Special Use Permit	Stormwater is not opposed to the special use permit. The applicant is requesting a SUP for the purpose of renewing the existing special use permit for a temporary golf pro-shop. Parcels 34546-122-00, 34546-123-00, & 34546-127-00 are currently zoned PUD and are collectively 2.17 acres in size. There are no FEMA Flood Zones or County Flood Prone Areas on this site. Per the MCPA, parcels 34546-122-00 & 34546-127-00 currently have 0 SF of impervious coverage while parcel 34546-123-00 currently has 19,072 sf of impervious coverage. This site will be subject to a Major Site Plan or waiver when its existing and proposed impervious coverage exceeds the impervious coverage Per ARs 2540 & 3341.	INFO	ENGDRN
3	Special Use Permit	5/12/25 RECOMMEND APPROVE – Operation already exists, and no changes are being proposed. County traffic is unaware of any existing issues with the current operation.	INFO	ENGTRF
4	Special Use Permit	No issue with Fire	INFO	FRMSH
5	Special Use Permit	no comment	INFO	LSCAPE
6	Special Use Permit	The review will be conducted at the time of the reporting process.	INFO	LUCURR
7	Special Use Permit	Parcels 34546-122-00, 34546-123-00, and 34546-127-00 are located within the FGUA service territory. The special permit application is for the continued use of a temporary Golf Pro-Shop. Please note that FGUA is not part of the Marion County Development Review process. The applicant must notify FGUA of the continued use of water and any associated additional wastewater flows	INFO	UTIL
8	Special Use Permit	The review will be conducted at the time of the reporting process.	INFO	ZONE