



SUBMITTAL SUMMARY REPORT 33189

PLAN NAME: NEIGHBORHOOD STORAGE PHASE 2	LOCATION: 7305 SW 80TH AVE OCALA,
APPLICATION DATE: 08/12/2025	PARCEL: 35466-003-00

DESCRIPTION:

CONTACTS	NAME	COMPANY
Applicant	Tillman Associates	Tillman & Associates Engineering, LLC
Applicant	Tillman Associates	Tillman & Associates Engineering, LLC
Engineer of Record	Tillman Associates	Tillman & Associates Engineering, LLC
Engineer of Record	Tillman Associates	Tillman & Associates Engineering, LLC

SUBMITTAL	STARTED	DUE	COMPLETE	STATUS
OCE: Plan Review (DR) v.	08/29/2025	09/19/2025	11/13/2025	Requires Re-submit
OCE: Plan Review (DR) v.	12/08/2025	12/15/2025	01/16/2026	Requires Re-submit
OCE: Plan Review (DR) v.	02/05/2026	02/12/2026	02/25/2026	Approved

SUBMITTAL DETAILS

OCE: Plan Review (DR) v.1

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
911 Management (DR) (911 Management)		09/19/2025	11/09/2025	Requires Re-submit
<i>Comments</i>	YES 2.12.8 - Legal description matches boundary on plan NO 2.12.28 - Correct road names supplied Sheet 03.01 There is a private drive that is labeled as SW 76th Ave. Please remove label from future submittals. YES 6.2.1.F - North arrow and graphic drawing and written scale N/A Additional 911 comments			
Environmental Health (Plans) (Environmental Health)		09/19/2025	11/09/2025	Approved
<i>Comments</i>	YES Central Sewer Central Sewer N/A Lot Size N/A Total Flow N/A Available Area YES DEP Water Approval Central Water N/A Operating Permit Required N/A 2.12.6 - Location of septic systems & wells N/A 2.12.36 - Location of water & septic systems INFO Additional Health comments Central Sewer/Central Water			
Fire Marshal (Plans) (Fire)		09/19/2025	11/09/2025	Approved
<i>Comments</i>	YES 6.18.2 - Fire Flow/Fire Hydrant YES 6.18.3 - Gated Communities/Properties N/A 6.18.4 - Wildland Interface Area INFO 6.18.5 - Access Control Box Any commercial building which contains a fire sprinkler system and or fire alarm system must install an access control box. The access control box must be ordered on a specific form signed by MCFR to ensure the correct box is ordered for the jurisdiction. Please contact our office to obtain the form 352-291-8000. YES 6.18.2.D - Fire Department Connections INFO NFPA 1 Chapter 11.10.1 - In Building Minimum Radio Signal Strength All new buildings and buildings which conduct renovations increasing the total floor space by greater than 50 percent of the floor area must comply with NFPA 1 Chapter 11.10.1. NFPA 1 Chapter 11.10.1 provides for the AHJ to establish minimum standards for in building public safety radio communications. Please be aware that your building will be required to conduct a test for the minimum radio signal strength to determine coverage. If the minimum radio signal strength is deemed insufficient then a radio signal enhancement system must be installed and the building retested to ensure it meets the minimum criteria. Please plan for this early in your project and contact Marion County Fire Rescue with any questions 352-291-8000. YES 6.18.2.G - Painting and Marking of Fire Hydrants YES NFPA 1 Chapter 18.2.3 - Fire Dept Access Roads N/A Additional Fire comments			

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
Growth Services Planning & Zoning (DR) (GS Planning and Zoning)		09/19/2025	11/09/2025	Requires Re-submit

Comments

ZONING-REJECT

YES 2.12.4.C - Owner and applicant name
 YES 2.12.4.L(1) - Parcel number
 YES 2.12.21/6.3.1.C(10) - Land use and zoning on project and on adjacent properties shown
 NO 2.12.4.L(4) - Zoning requirements: lot width, area, setbacks, coverage (floor area ratios) and parking Include in title block zoning requirements for PUD including lot width, area, setbacks, coverage, parking, and building height.
 NO 2.12.23/4.2 -Setbacks, dimensions for all improvements, and easements label and include setbacks/easements
 YES 2.12.24 - Landscape requirements/6.8.6 - Buffering
 YES 2.12.4.L(7) - List and describe land use including floor area of particular use (example: office, warehouse, storage or assembly) these descriptions are often found in the summary of parking requirements but should be clearly shown on plan
 INFO 2.12.6 - Location of water and sewer. Does this need a special use permit? defer to mcu
 YES 2.12.9 - Show adjacent streets serving development
 YES 2.12.32 - Show 100yr flood zone
 YES 2.12.32 - Modified Environmental Assessment for Listed Species (LDC 6.5.4) -OR- EALS Exemption Application (LDC 6.5.3) submitted (including habitat assessment as necessary per LDC 6.6.4) Submitted to FWC on 9/17/25
 NO 2.12.4.L(10) - Parking requirements, service entrances, space size paved parking isle and access to parking area/6.11.8 - Off-street parking requirements/6.11.7 - Loading Areas/ 6.11.6 - Construction access/route Include parking requirements and construction access/route.
 INFO 4.4.4 -Sign (provisions for advertising signage), if it is a multi occupancy complex like shopping centers they must submit a master sign plan. include Location, dimensions and setbacks of signage if proposed.
 YES 2.12.19 - Provide dimensions and location of all existing site improvements; dimensions and location for all proposed site improvements with all setbacks
 INFO 2.12.27 - Show location of outside storage areas Include location, and screening of outside storage/garbage.
 YES 5.2 & 5.3 - Verify any overlay zones such as ESOZ, Springs Protection, or Flood Plain Secondary Springs Protection Zone, Flood Zone X, No ESOZ
 N/A Additional Zoning comments

LAND USE-APPROVED

YES 2.12.4.L(2)/3.2.3 - Use Consistent with FLU Designation?
 YES 2.12.4.L(3) - All applicable Developer's Agreements listed?
 N/A 2.12.4.L(2,3, & 5)/6.3.1C(15)(g) - DRI/FQD Compliance Note?
 N/A 3.2.3/6.6/5.2.5/flood - RESIDENTIAL - Complies with Min/Max Density?
 YES 3.2.3 - NON-RESIDENTIAL - Complies with FAR?
 YES 2.12.4.L(6) - Gross/wetland/floodplain acreage listed?
 N/A 3.3.2.C - Complies with Approved ECSD PUD?
 N/A 3.3.3.A(1)- Complies with Approved Rural Residential Cluster Plan?
 N/A 3.3.3.A(2) - Complies with Approved Hamlet Plan?
 N/A 2.12.4.L(5)/5.2 - [Applicable ESOZ/FPOZ Status Listed?]
 YES 2.12.4.L(5)/5.4 - [Applicable Springs Protection Zone Listed?]
 N/A 2.12.4.L(5)/5.7 - Wellhead Protection - P/S/T Zones Shown/Listed?
 YES 2.12.4.L(7 & 9) - Building Uses/Identifiers/Designations Provided for 911?
 N/A 4.1.4.J - [Greenway Setback Provided?]
 N/A 2.12.16/6.5 - [EALS or EALS-ER provided?]
 N/A 6.5 & 6.6 - Habitat Preservation/Mitigation Provided?
 YES 2.12.9 - [Show All Existing Surrounding & Intersecting R/Ws?]
 YES 6.12.2.A - [Local Road right-of-Way Provided?]
 YES 6.12.2.A - [Access Improvements R/W Provided (decel/accel/turn lanes)?]
 N/A 2.12.9/6.12.2.B - Comp Plan Future Thoroughfares R/W Provided (TE Map)?
 YES 6.11.4.C - [Additional/Alternate/Interconnected Access (S/QS-L) Provided?]
 YES 6.11.2, 4 & 5 - Internal Access Consistent with PUD/Master Plan/Plat?
 N/A 6.11.4.B & D/7.3.1 - [Cross/Parallel Access Required/Suitable?]
 YES 6.11.5 -[Driveways to Intersections Separated/Coordinated?]
 N/A 6.11.4.E - [Sight Triangle Provided?]
 N/A 6.11.5 - [Driveways to Driveways Separated/Coordinated?]
 N/A 6.12.12 - [Sidewalks Internal/External Provided?]
 YES 2.12.5/1.8.2.A - Concurrency/Traffic - Study/Capacity Available?
 YES 2.12.5/1.8.2.D - Concurrency - PRELIM Evaluation Required?
 YES 2.12.5/1.8.2.F - Is Concurrency Approval or Deferral Elected?
 YES 2.12.6, 35, & 36/6.14 - [Concurrency/Water Provided?]
 YES 2.12.6, 35, & 36/6.14 - [Concurrency/Sewer Provided?]
 N/A Additional Planning Items:

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
Landscape (Plans) (Parks and Recreation)		09/19/2025	11/09/2025	Requires Re-submit
<i>Comments</i>	PEND 2.12.18 - All trees 10" DBH and larger PEND 2.12.25 - Marion Friendly Landscape Areas PEND 6.7.3 - Tree protection PEND 6.7.4 - Shade tree requirements PEND 6.7.6 - Tree removal submittal requirements PEND 6.7.8 - Protected tree replacement requirements PEND 6.7.9 - Replacement trees; general requirements PEND 6.8.2 - Landscape plan requirements (details, schedule, calculations, notes) PEND 6.8.3 - Landscape design standards PEND 6.8.4 - Landscape area requirements for non-residential development PEND 6.8.5 - Landscape area requirements for residential and mixed use developments PEND 6.8.6 - Buffers PEND 6.8.7 - Parking areas and vehicular use areas PEND 6.8.8 - Building landscaping PEND 6.8.9 - Service and equipment areas PEND 6.13.3.C(5) - Landscaping of public stormwater management facilities PEND 6.13.3.D(4) - Landscaping of private stormwater management facilities PEND 6.8.10 - General planting requirements (specifications) PEND 6.8.11 - Landscape installation PEND 6.8.12 - Landscape completion inspection requirements PEND 6.9.2 - Irrigation plan requirements (details, legend, notes) PEND 6.9.3 - Irrigation design standards PEND 6.9.5 - Irrigation system installation PEND 6.9.6 - Completion inspection requirements PEND 6.19.3 - Outdoor lighting plan requirements PEND 6.19.4 - Exterior lighting design standards PEND 5.5.4.B - Permitted uses within Springs Protection Overlay Zone NO Additional Landscape comments Please submit Tree preservation, Landscape and Irrigation plans for review			
OCE Design (Plans) (Office of the County Engineer)		09/19/2025	11/09/2025	Approved
<i>Comments</i>	YES 2.21.2.B - Major Site Plan fee of \$1,000.00 + (\$10.00 x total site acreage) 10/23/25-fee due with resubmittal N/A 2.21.2.B - Plan review fee of \$40.00 made payable to Marion County Health Department N/A Traffic study / methodology fee of \$200.00 made payable to Marion County BCC is required prior to plan approval. Refer to Resolution 10-R-630 for the current fee schedule. N/A 2.1.6.A - \$100 Resubmittal fee payable to Marion County BCC N/A 2.1.7.A - \$100 Revision fee payable to Marion County BCC N/A 2.1.3 - Order of plan approval YES 2.12.3 - Title block on all sheets denoting type of application; project name, location, county, and state; and date of original and all revisions YES 2.12.4.A - Type of application on front page YES 2.12.4.B - Project name centered at top of front page YES 2.12.4.C - Name, address, phone number, and signature of owner and applicant on front sheet YES 2.12.4.D - Owner's certification on front sheet: I hereby certify that I, my successors, and assigns shall perpetually maintain the improvements as shown on this plan YES 2.12.4.E - The name, address, phone number, signature, date, license number, and seal of the responsible professional shall be shown on each plan sheet YES 6.2.1.A - Name, street address, signature, date, license number, and seal of licensed professional on each sheet YES 2.12.4.F - Licensed professional certification on cover sheet with signature and seal on all sheets after plan approval YES 2.12.4.F(1) - Licensed Design Professional Certification: I hereby certify that these plans and calculations were completed in accordance with all applicable requirements of the Marion County Land Development Code, except as waived. YES 2.12.4.G - A key location or vicinity map, with north arrow, with reference to surrounding properties, streets, municipal boundaries, sections, ranges, and township YES 2.12.4.H - A portrait oriented minimal 3 inches x 5 inches space, located 2.75 inches from the right edge of paper and .75 inches from the top edge of paper, shall remain blank to allow for a County approval stamp YES 2.12.4.I & 6.2.1.D - Index of sheets and numbering INFO 2.12.4.K - List of approved waivers, their conditions, and the date of approval 10/23/25-add waivers if requested in future PEND 2.12.4.L(1) - Parcel number PEND 2.12.7 - A digital version of the plan in a format pre-approved by the Office of the County Engineer PEND 2.21.2.A - Multi-phase Major Site Plans may include a separate sheet showing independent, stand alone phasing and shall not be subject to a separate Master Plan application PEND 6.2.1.B - Plans shall be legible and meet typical industry standards PEND 6.2.1.C - Standardized sheet size shall be 24" x 36" PEND 6.2.1.F - North arrow and graphic drawing and written scale PEND Legal Documents PEND Additional Development Review Comments After approval, plans will be electronically stamped by the County. The applicant will receive an email indicating that approved plans are available for download and are located in the ePlans project Approved folder. For Development Review submittals, with the exception of Final Plats and Minor Site Plans, applicants are required to print, obtain required signatures, and sign and seal two 24"x 36" sets of the electronically stamped approved plan and deliver them to the Office of County Engineer, Development Review Section, located at 412 SE 25th Avenue Ocala, FL 34471. Upon receipt, a development order will be issued. Until such time as that development order is issued, the project does not have final approval and construction, if applicable, shall not commence. For plans requiring As-Builts, As-Builts and associated documentation shall be submitted on paper in accordance with current county requirements.			

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
OCE Property Management (Plans) (Office of the County Engineer)		09/19/2025	11/09/2025	Approved

Comments INFO Major Site Plan Sunbiz and Project map checked -EMW 9.4.25

IF APPLICABLE:

Sec. 2.18.1.I - Show connections to other phases.

Sec.2.19.2.H – Legal Documents

Legal documents such as Declaration of Covenants and Restrictions, By-Laws, Articles of Incorporation, ordinances, resolutions, etc.

Sec. 6.3.1.B.1 – Required Right of Way Dedication (select as appropriate)

For Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated for the use and benefit of the public."

Sec. 6.3.1.B.2 – Required Right of Way Dedication

For Non-Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated privately to the [entity name]. All public authorities and their personnel providing services to the subdivision are granted an easement for access. The Board of County Commissioners of Marion County, Florida, shall have no responsibility, duty, or liability whatsoever regarding such streets. Marion County is granted an easement for emergency maintenance in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."

Sec. 6.3.1.D.3 - Cross Access Easements

For Cross Access Easements. "All parallel access easements shown on this plat are hereby dedicated for the use and benefit of the public, and maintenance of said easements is the responsibility of [entity name]."

Sec. 6.3.1.C.1 - Utility Easements (select as appropriate)

"[All utility easements shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction, installation, maintenance, and operation of utilities by any utility provider."

Sec. 6.3.1.C.2 – Utility Easements

"[All utility tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."

Sec.6.3.1.D(c)(1)(2)(3) - Stormwater easements and facilities, select as appropriate:

1. "[All stormwater and drainage easements as shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction and maintenance of such facilities."

2. "[All stormwater management tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."

3. When any stormwater easement and/or management tract is not dedicated to the public or Marion County directly, the following statement shall be added to the dedication language: "Marion County is granted the right to perform emergency maintenance on the [stormwater easement and/or management tract, complete accordingly] in the event of a local, state, or

federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."

Sec.6.3.1.D(f) –

If a Conservation Easement is required the following shall be provided: "A conservation easement [as shown or on tract and identify the tract, complete accordingly] is dedicated to [the Board of County Commissioners of Marion County, Florida or entity name, if not Marion County] for the purpose of preservation of [listed species, habitat, Karst feature and/or native vegetation, complete accordingly]."

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
OCE Stormwater (Permits & Plans) (Office of the County Engineer)		09/19/2025	11/09/2025	Requires Re-submit
<i>Comments</i>	<p>YES 2.12.4.L(9)(b) - Data Block (Impervious Area)</p> <p>YES 2.12.8 - Topographical Contours</p> <p>YES 2.12.9/10 - Existing Drainage Right-of-Way/Easements</p> <p>N/A 2.12.9/10 - Proposed Drainage Right-of-Way/Easements</p> <p>N/A 2.12.13/14/15 - General Exhibits</p> <p>N/A 2.12.20 - Stormwater Infrastructure Supports Phasing</p> <p>NO 2.12.38 - Stormwater Maintenance Entity Please provide documentation establishing that Scott Cunningham can sign on behalf of the applicant/owner.</p> <p>N/A 6.13.2.C - Geotechnical Investigation Report</p> <p>N/A 6.13.7 - Geotechnical Criteria</p> <p>YES 6.13.2.A(1)/(2) - Contributing Basins/Tc</p> <p>YES 6.13.2.B(1)/(2) - Runoff Analysis/ Tc Calculations</p> <p>YES 6.13.2.A(4) - Stormwater Features & Connective Elements</p> <p>N/A 6.13.2.A(3) - Retention/Detention Area Design Parameters</p> <p>N/A 6.13.3 - Type of Stormwater Facility Criteria</p> <p>YES 6.13.4 - Stormwater Quantity Criteria</p> <p>YES 6.13.2.B(4) - Hydrologic Analysis</p> <p>YES 6.13.4.C - Discharge Conditions</p> <p>YES 6.13.2.B(6) - Freeboard</p> <p>YES 6.13.4.D - Recovery Analysis</p> <p>N/A 6.13.5 - Flood Plain & Protection</p> <p>YES 6.13.2.A(8) - Finish Floor Elevation Criteria</p> <p>N/A 6.13.6 - Stormwater Quality Criteria</p> <p>N/A 6.12.6 - Roadway Flooding Level of Service</p> <p>N/A 6.13.6.B - Alternative Treatment Techniques</p> <p>YES 6.13.6.C - Best Management Practices</p> <p>YES 6.13.8 - Stormwater Conveyance Criteria</p> <p>YES 6.13.2.B(5) - Hydraulic Analysis</p> <p>N/A 6.13.8.B(3) - Lane Spread Calculations</p> <p>N/A 6.13.2.A(9) - Access Accommodates Stormwater</p> <p>YES 6.13.8.B(7) - Minimum Pipe Size</p> <p>YES 6.13.2.A(5) - Existing/Proposed Stormwater Structures</p> <p>YES 6.13.2.A(6) - Existing/Proposed Stormwater Pipes</p> <p>YES 6.13.2.A(7) - Existing/Proposed Stormwater Swales</p> <p>NO 6.13.9 - Grading Criteria Please clarify which direction the roof of Building 'G' will drain (east or west). If is pitched and will drain to the east a swale or roof drains may be necessary to get these flows to the appropriate conveyance system. Based on the hydraulic calculations it appears to be draining to the west. Please clarify.</p> <p>YES 6.13.2.A(11)(a) - Construction Entrance</p> <p>YES 6.13.2.A(11)(b) - Erosion Control</p> <p>YES 6.13.2.A(12)/6.12.5 - Stormwater Details, Cross Sections, References</p> <p>INFO 6.13.2.B(8) - Calculation & Plan Consistency This criteria to be reviewed with resubmittal.</p> <p>INFO 6.13.10.B - Copy of NPDES Permit or NOI Please provide a copy of the NPDES permit or NOI prior to construction.</p> <p>INFO Copy of District Permit (County Interest) Please provide a copy of the District permit prior to construction.</p> <p>N/A 6.10 - Karst Topography and High Recharge Areas</p> <p>YES 7.1.3 - Drainage Construction Specifications</p> <p>NO 6.13.12 - Operation and Maintenance Please provide an O&M manual detailing the steps for operating and maintaining the proposed system of inlets and pipes. An owner's certification is required on the O&M manual. Certification to state "I hereby certify that I, my successor, and assigns shall perpetually operate and maintain the stormwater management and associated elements in accordance with the specifications shown herein and on the approved plan." The individual signing the certification needs to be an agent or member of the entity that will own and maintain the stormwater system, or an authorized signatory of that entity. If signatory is not an agent or member, a letter authorizing a different individual needs to be submitted with the signed documents. The authorization letter must be signed by and agent/officer of owner. Please have the person signing also print their name for verification. Sunbiz will be used to verify agents and/or officers. Please contact reviewer if you need examples of O&M manuals accepted in the past.</p> <p>NO Please provide a final signed and sealed hard copy signature page with references to the stormwater analysis or final hard copy of the full stormwater analysis. Please submit signed and sealed drainage report.</p> <p>INFO Additional Stormwater comments If you have questions or would like to discuss the stormwater review comments, please contact Kevin Vickers, PE at 352-671-8695 or kevin.vickers@marionfl.org.</p>			

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
OCE Survey (Plans) (Office of the County Engineer)		09/19/2025	11/09/2025	Approved
<i>Comments</i>	YES 6.2.1.A - The name, street address, signature, date, license number, and seal of the responsible professional shall be shown on each plan sheet. YES 6.2.1.E - Provide drawing legend YES 6.2.1.F - Provide north arrow and graphic drawing and written scale YES 6.4.7.A(1) - Show a minimum of two bench marks per site YES 6.4.7.A(2 & 3) - Bench mark information shown N/A 6.4.7.A(2 & 3) - One copy of the vertical control field notes shall be submitted to the Office of the County Engineer for review PEND 6.4.7.B(1) - Show a minimum of two intervisible horizontal control points per site YES 6.4.7.B(2) - Horizontal control points shall be monumented and referenced to the Florida State Plane Coordinate System YES 6.4.7.B(4) - Provide a statement or table detailing horizontal datum, adjustment, and coordinate values N/A 6.4.7.B(4) - One copy of the horizontal control notes along with reduction reports shall be submitted to the Office of the County Engineer for review YES 6.4.7.D - The location of the existing one percent (100-year) flood plain as shown on FEMA FIRM, with zone, elevation, and vertical datum noted YES 6.4.7.D - A note shall appear on the construction plans detailing source and survey field methods used to obtain and delineate the flood plain line shown YES 6.4.7.E - Line and curve table must be shown on the sheet to which they apply YES 6.4.7.F - All abbreviations used shall be clearly defined in the legend YES 2.12.4.F.(2) - Surveyor and Mapper certification YES 2.12.4.G - Show a location or vicinity map YES 2.12.8 - Provide current boundary and topographic survey less than one year old YES 2.12.9 - Provide location and dimensions of all rights-of-way serving the project YES 2.12.10 - Show any known existing or proposed easement or land reservation YES 2.12.11 - Provide an aerial map of the site with a layout of the development YES 2.12.32 - Provide site analysis map depicting the existing (100-year) flood plain N/A Additional Survey comments			
OCE Traffic (Permits & Plans) (Office of the County Engineer)		09/19/2025	11/09/2025	Approved
<i>Comments</i>	YES 2.12.9 - Location and dimensions of streets and right-of-way YES 2.12.20 - Phases of development N/A 2.12.30 - Route Plan N/A 2.12.38 - Maintenance of improvements YES 6.2.1.E - Drawing legend N/A 6.11.3 - Traffic Impact Analysis N/A 6.11.4.B - Cross access N/A 6.11.4.E - Sight triangle N/A 6.11.5 - Driveway access N/A 6.11.6 - Construction route N/A 6.11.9.A - Traffic signals N/A 6.11.9.B - Traffic signs N/A 6.11.9.C - Pavement marking N/A 6.12.1.A - Transportation Facilities - Purpose and Intent N/A 6.12.2 - Right-of-way N/A 6.12.11 - Turn lanes N/A 6.12.12 - Sidewalks N/A 6.12.13 - Utility position in right-of-way N/A Additional Traffic comments			
Utilities (OCE Plans) (Utilities)		09/19/2025	11/09/2025	Requires Re-submit

SUBMITTAL SUMMARY REPORT (33189)

Comments

YES Marion County Utilities Contact Information Correct on 01.01 Cover Sheet
YES Parcel numbers identified in project match proposed site plan layout Portion of Parcel 35466-003-00
INFO 6.14.2.A(1) - Public water service area/provider Marion County Utilities
INFO 6.14.2.A(1) - Public sewer service area/provider Marion County Utilities
N/A 6.14.2.A(1) - Letter of Availability and Capacity (w/Location Map of water and/or sewer as app) from provider
INFO 6.14.2.A - Water Connection Requirements 05.01 - All utilities shown will remain private - Please note on Utility Plan and as-builts.
INFO 6.14.2.A - Sewer Connection Requirements 05.01 - All utilities shown will remain private - Please note on Utility Plan and as-builts.
N/A 6.14.2.C.2(e) - Grease Trap, FOG Worksheet
N/A 6.14.2.C - Industrial Pretreatment
N/A 6.14.3 - Onsite Waste Treatment and Disposal System (OSTDS) - connection requirement on plan
YES 6.14.3.B - Springs Protection Zone Secondary. Within the Urban Growth Boundary
INFO 6.14.4 - Water (potable) Capital Charges and Flow Rates - proposed use identified to calculate Capital charges and flow rates will be calculated during the permitting stage, before approval.
NO 6.14.4 - Water (irrigation) Capital Charges and Flow Rates - total irrigated area identified How will this site be irrigated? Phase 1 AR# 24090 shows irrigation service. If service continues onto phase 2, provide irrigated square footage.
INFO 6.14.4 - Sewer Capital Charges and Flow Rates - proposed use identified to calculate Capital charges and flow rates will be calculated during the permitting stage, before approval.
YES 6.14.5.A(1) - Submittal Requirements - Existing on-site & off-site mains and service connections
N/A 6.14.5.A(2) - Submittal Requirements - Proposed on-site & off-site mains and service connections
N/A 6.14.5.A(3) - Submittal Requirements - Lift Stations layout, elevations, schedules
N/A 6.14.5.A(6) - Submittal Requirements - Manhole locations, rim and invert elevations outside paved areas
YES 6.14.5.A(8) - Submittal Requirements - Connection to existing water system Connecting to existing stub outs from phase 1 AR# 24090
YES 6.14.5.A(8) - Submittal Requirements - Connection to existing sanitary system Connecting to existing stub outs from phase 1 AR# 24090
YES 6.14.5.B - Construction Notes - Cover, horiz/vert datums, construction requirements
INFO 6.14.5.B - Construction Notes - UT DETAILS - current LDC version The contractor will be required to install the version of the MCU-approved details in effect at the time the plan is approved.
INFO 6.14.5.C - All issued permits related to this project shall be submitted to MCU (DOT, ROW, misc) Copies of all related permit applications and issued permits shall be submitted to the Development Reviewer for Marion County Utilities Department. (LDC 6.14.5.C).
N/A 6.14.5.C - DEP permit for water mains to be constructed/owned by MCU
YES 6.14.5.C - DEP permit for water mains to be constructed/owned by developer
N/A 6.14.5.C - DEP permit for sewer mains to be constructed/owned by MCU
YES 6.14.5.C - DEP permit for sewer mains to be constructed/owned by developer
INFO 6.14.5.D - Hydraulic Analysis The Hydraulic Analysis has not been provided for this site. (LDC 6.14.5.C)

N/A 6.14.6 - Design Criteria for Utility Systems to be owned/maintained by MCU
INFO 6.14.7 - Construction Inspection - PLAN NOTE: Add to Utilities Plan: MCU personnel are to inspect any work performed on or around existing MCU infrastructure. A pre-construction meeting is required to be held a minimum of 48 hours prior to start of any construction. If the pre-construction meeting is not completed, any work may be halted. To schedule, contact MCU's Construction Division, 352) 307-6000, ext. 5 or MCUconstruction@marionfl.org

INFO 6.14.8.A - Completion and Closeout - PLAN NOTE: As-builts All as-builts shall comply with the current Marion County LDC, section 6.14.8
N/A 6.14.9.A - Developer's Agreement
N/A 6.14.9.B - Transfer of Facilities to Marion County Utilities - PLAN NOTE:
INFO 6.14.9.B - Bill of Sale All infrastructure being installed is to remain private. A Bill of Sale will not be required by MCU.
N/A 6.15.1 - Potable Water Distribution System
N/A 6.15.2 - Decentralized Water System (WTP)
INFO 6.15.3 - Fire Protection/Fire Flow Capacity All Hydrants are to be painted Yellow. (2) Water service will be provided by Marion County Utilities. Please consult with Marion County Fire Rescue for any additional comments or requirements related to fire protection.
"

N/A 6.15.4 - Water Main Piping Installation
YES 6.15.5 - Water Service and Connection
N/A 6.15.6.A - Potable Water Metering - individual/banked, size
INFO 6.15.6.B - Irrigation Water Metering - size 2" Proposed meter on Phase 1 - AR#24090.
N/A 6.15.6.C - Sewer service only (water meter required/shown)
N/A 6.15.6.D - Meter Location Meters were installed in Phase 1 - AR# 24090
N/A 6.15.6.E - Meter Easements
N/A 6.15.6.F - Meter Boxes
N/A 6.15.6.G & H - Meter Sizing
N/A 6.15.7 - Cross Connection Control and Backflow Prevention
N/A 6.15.8 - Public Water Well Standards
N/A 6.15.9 - Wellfield and Water Supply
N/A 6.15.10 - Water Treatment Plants (WTP)
N/A 6.16.2 - Decentralized Wastewater Treatment Plant (WWTP)
N/A 6.16.4 - Wastewater Collection Systems (Gravity/Pressurized) Design
N/A 6.16.5.A & B - Private Wastewater Pump Stations
N/A 6.16.5.C - Public Wastewater Pump Stations (MCU Standards)
N/A 6.17 - Water Reclamation/Reuse Facilities
INFO Article 7 - Construction Standards - PLAN NOTE: All facilities constructed on the developer's property prior to interconnection with Marion County Utility's existing or proposed facilities, shall convey such component parts to MCU by bill of sale in a form satisfactory to the County Attorney, with the following evidence required by MCU: Refer to LDC 6.14.9 (B).

INFO Utilities Plan Review Fee per Resolution 15-R-583 - payable to Marion County Utilities Utilities Plan Review Fee: \$130.00 Fee (s) can be paid by calling 352-671-8686 or visiting the Development Review Office at 412 SE 25th Ave, Ocala, FL 34471. Reference AR# ENTER AR #

SUBMITTAL SUMMARY REPORT (33189)

INFO Additional Utilities comments Please add the parcel numbers of the surrounding parcels for orientation as this project is only situated on a portion of the parcel listed.

INFO Additional Utilities comments For any questions regarding this review, please contact Heather Proctor, Utilities Development Review Officer, at Heather.Proctor@marionfl.org or by phone at (352) 438-2846.

NO Additional Utilities comments Revise the General Notes to state: All utility infrastructure will remain private and will be privately maintained.

PEND Additional Utilities comments

OCE: Plan Review (DR) v.2

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
911 Management (DR) (911 Management)	Caroline Dennison	12/15/2025	12/15/2025	Approved
Environmental Health (Plans) (Environmental Health)	Evan Searcy	12/15/2025	12/23/2025	Approved
Fire Marshal (Plans) (Fire)	Jonathan Kenning	12/15/2025	12/08/2025	Approved
<i>Comments</i>	Previously approved			
Growth Services Planning & Zoning (DR) (GS Planning and Zoning)	Xinyi Chen	12/15/2025	12/17/2025	Requires Re-submit
<i>Corrections</i>	6.5 & 6.6 - Habitat Preservation/Mitigation (Resolved) - 6.5 & 6.6 - Habitat Preservation/Mitigation: Refer to LDC Sec. 6.6 for requirements and design standards if the site contains open water, wetland, listed species, native habitat vegetation, and/or natural open space. When a proposed development or land clearing site is found to include listed species, the application shall identify species and habitat protection as on-site or off-site. The selected option shall be a condition of approval and shall be completed at time of final inspection.			
<i>Corrections</i>	2.12.27 - Location & screening of outside storage (Resolved) - 2.12.27 - Location & screening of outside storage: Provide a statement indicating any outside storage area is proposed. If applicable, show location of outside storage areas on plan. Check special requirements under zoning code sections.			
<i>Corrections</i>	2.12.22 - Tracts (Not Resolved) - 2.12.22 - Tracts : Show existing and proposed tracts on plan, and provide description of each tract.			
<i>Corrections</i>	2.12.24 - Landscape requirements/6.8.6 - Buffering (Not Resolved) - 2.12.24 - Landscape requirements/6.8.6 - Buffering: Show buffer types, locations, and dimensions of required buffering on plan. Show buffer descriptions and illustrations of each proposed buffer (including longitudinal and transverse cross-sections)			
<i>Corrections</i>	2.12.4/6.11.6 - Construction access (Not Resolved) - 2.12.4/6.11.6 - Construction access: Show proposed construction access and route on plan, per Sec. 6.11.6. - Construction access/route,.			
<i>Corrections</i>	2.12/2.12.21 - Open space and natural areas (Not Resolved) - 2.12/2.12.21 - Open space and natural areas: Provide list of open space and natural areas in square footage, acreage, and percentage. Including existing and proposed natural open space, improved open space, open water, wetland, and preserved natural areas. Also show them on the plan.			
<i>Corrections</i>	2.12.4/6.11.7 - Loading area (Not Resolved) - 2.12.4/6.11.7 - Loading area: Show proposed loading areas on plan, per Sec. 6.11.7. - Loading areas.			
<i>Corrections</i>	2.12/4.2 - Lot setback (Not Resolved) - 2.12/4.2 - Lot setback: Provide required setback and proposed setback in the site data table and show them on the plan.			
<i>Corrections</i>	4.4 - Show proposed signs to meet LDC Sec 4.4 (Resolved) - 4.4 - Show proposed signs to meet LDC Sec 4.4: If sign(s) is proposed on site, show proposed sign's location and design. The signs shall comply with LDC Sec. 4.4. A master sign plan and/or permit may be required.			
<i>Corrections</i>	2.12.4/6.11.8 - Parking (Not Resolved) - 2.12.4/6.11.8 - Parking: Provide number and calculation of required and proposed parking spaces in table format, per LDC Sec. 6.11.8. - Parking requirements.			
Landscape (Plans) (Parks and Recreation)	Susan Heyen	12/15/2025	12/09/2025	Requires Re-submit
<i>Comments</i>	See markups on plan			
OCE Design (Plans) (Office of the County Engineer)	Jack Dingman	12/15/2025	01/16/2026	Approved
<i>Corrections</i>	2.12.4.I & 6.2.1.D - Index of sheets and numbering (Resolved) - 2.12.4.I & 6.2.1.D - Index of sheets and numbering: Index of sheets; All sheets shall indicate each sheet number and the total number of sheets. Cross references between sheets is required			
<i>Corrections</i>	6.2.1.B.-F. - Requirements (Resolved) - 6.2.1.B.-F. - Requirements: Technical standards and requirements as listed in Section 6.2.1.B. through F. of the LDC			
<i>Corrections</i>	2.18.2.G Utility Easements (Resolved) - 2.18.2.G Utility Easements: Easement requirements of each utility shall be indicated by the utility on a copy of the Preliminary Plat or by letter. (Letters/emails of easement acceptance due with improvement plan.)			
<i>Corrections</i>	2.21.2.A - Multi-phase Major Site Plans (Resolved) - 2.21.2.A - Multi-phase Major Site Plans: Multi-phase Major Site Plans may include a separate sheet showing independent, stand alone phasing and shall not be subject to a separate Master Plan application			
<i>Corrections</i>	2.12.4.E & 6.2.1.A - Licensed Professional (Resolved) - 2.12.4.E & 6.2.1.A - Licensed Professional: 2.12.4.E & 6.2.1.A - The name, address, phone number, signature, date, license number, and seal of the responsible professional shall be shown on each plan sheet			
<i>Corrections</i>	2.21.2.A - Multi-phase Major Site Plans (Resolved) - 2.21.2.A - Multi-phase Major Site Plans: Multi-phase Major Site Plans may include a separate sheet showing independent, stand alone phasing and shall not be subject to a separate Master Plan application			
<i>Corrections</i>	2.12.4 - Front page of the plan (Resolved) - 2.12.4 - Front page of the plan: Front page of the plan shall minimally include A through L of this section of the LDC.			
<i>Corrections</i>	Legal Documents (Resolved) - Legal Documents			
<i>Corrections</i>	Additional Design Comments (Resolved) - Additional Comments:			

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
OCE Design (Plans) (Office of the County Engineer)	Jack Dingman	12/15/2025	01/16/2026	Approved
<i>Corrections</i>	2.12.3 - Title block (Resolved) - 2.12.3 - Title block: Title block on all sheets denoting type of application; project name, location, county, and state; and date of original and all revisions			
<i>Corrections</i>	6.2.1.A. - Licensed Professional (Resolved) - 6.2.1.A. - Licensed Professional: Plans shall be prepared by a professional licensed by the State of Florida. The name, street address, signature, date, license number, and seal of the responsible professional shall be shown on each plan sheet. The same shall be provided on the cover page of any supporting documents and calculations.			
OCE Property Management (Plans) (Office of the County Engineer)	Elizabeth Woods	12/15/2025	12/16/2025	Informational
<i>Comments</i>	Sunbiz and Project map checked -EMW 9.4.25//12.16.25			
	<p>IF APPLICABLE:</p> <p>Sec. 2.18.1.I - Show connections to other phases.</p> <p>Sec.2.19.2.H – Legal Documents Legal documents such as Declaration of Covenants and Restrictions, By-Laws, Articles of Incorporation, ordinances, resolutions, etc.</p> <p>Sec. 6.3.1.B.1 – Required Right of Way Dedication (select as appropriate) For Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated for the use and benefit of the public."</p> <p>Sec. 6.3.1.B.2 – Required Right of Way Dedication For Non-Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated privately to the [entity name]. All public authorities and their personnel providing services to the subdivision are granted an easement for access. The Board of County Commissioners of Marion County, Florida, shall have no responsibility, duty, or liability whatsoever regarding such streets. Marion County is granted an easement for emergency maintenance in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."</p> <p>Sec. 6.3.1.D.3 - Cross Access Easements For Cross Access Easements. "All parallel access easements shown on this plat are hereby dedicated for the use and benefit of the public, and maintenance of said easements is the responsibility of [entity name]."</p> <p>Sec. 6.3.1.C.1 - Utility Easements (select as appropriate) "[All utility easements shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction, installation, maintenance, and operation of utilities by any utility provider."</p> <p>Sec. 6.3.1.C.2 – Utility Easements "[All utility tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."</p> <p>Sec.6.3.1.D(c)(1)(2)(3) - Stormwater easements and facilities, select as appropriate:</p> <p>1. "[All stormwater and drainage easements as shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction and maintenance of such facilities."</p> <p>2. "[All stormwater management tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."</p> <p>3. When any stormwater easement and/or management tract is not dedicated to the public or Marion County directly, the following statement shall be added to the dedication language: "Marion County is granted the right to perform emergency maintenance on the [stormwater easement and/or management tract, complete accordingly] in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."</p> <p>Sec.6.3.1.D(f) – If a Conservation Easement is required the following shall be provided: "A conservation easement [as shown or on tract and identify the tract, complete accordingly] is dedicated to [the Board of County Commissioners of Marion County, Florida or entity name, if not Marion County] for the purpose of preservation of [listed species, habitat, Karst feature and/or native vegetation, complete accordingly]."</p>			
OCE Stormwater (Permits & Plans) (Office of the County Engineer)	Kevin Vickers	12/15/2025	12/15/2025	Approved
<i>Recommendations</i>	Additional Stormwater comments - If you have questions or would like to discuss the stormwater review comments, please contact Kevin Vickers, PE at 352-671-8695 or kevin.vickers@marionfl.org.			
<i>Recommendations</i>	6.13.10.B <input type="checkbox"/> Copy of NPDES Permit or NOI - Please provide a copy of the NPDES permit or NOI prior to construction.			
<i>Recommendations</i>	Copy of District Permit (County Interest) - Please provide a copy of the District permit prior to construction.			
OCE Survey (Plans) (Office of the County Engineer)	Theresa Smail	12/15/2025	12/17/2025	Approved
OCE Traffic (Permits & Plans) (Office of the County Engineer)	Chris Zeigler	12/15/2025	12/10/2025	Approved
Utilities (OCE Plans) (Utilities)	Heather Proctor	12/15/2025	12/17/2025	Approved
<i>Comments</i>	Approved with Recommendation comment(s) - Project 33189 will be connecting to Phase 1 of construction, which is connected to Marion County Utility (MCU) water and wastewater.			
<i>Recommendations</i>	Sheet 05.01 - Fix leader showing (2) 8" - 45" BENDS - Its pointed at the proposed fire hydrant currently.			
eREVIEW SESSION FILES:	27477 Ocala FL 8-18-25 dev_Certificate of Secretary.pdf File Category Placeholder.pdf Neighborhood Storage Phase 2 Stormwater Report S&S.pdf O&M Letter Signed.pdf Response Letter 2025.11.24.pdf			
REVIEWER	MARKUP	DATE/TIME	FILE NAME	PG #
Susan Heyen	Waiver required for shade tree reduction	12/09/2025 1:29	PMFile Category Placeholder.pdf	15
Susan Heyen	1. Provide landscape area calculation showing 20% is met2.	12/09/2025 1:31	PMFile Category Placeholder.pdf	15

SUBMITTAL SUMMARY REPORT (33189)

eREVIEW SESSION FILES: 27477 Ocala FL 8-18-25 dev_Certificate of Secretary.pdf
 File Category Placeholder.pdf
 Neighborhood Storage Phase 2 Stormwater Report S&S.pdf
 O&M Letter Signed.pdf
 Response Letter 2025.11.24.pdf

REVIEWER	MARKUP	DATE/TIME	FILE NAME	PG #
Susan Heyen	1. Confirm no windows or doors on side of buiding to serve as wall. Waiver required to use building as wall	12/09/2025 1:33	PMFile Category Placeholder.pdf	16
Susan Heyen	1. Is there a dumpster on site? If so, please show screening	12/09/2025 1:34	PMFile Category Placeholder.pdf	16
Susan Heyen	1. Will there be outdoor lighting? If so, please submit a signed and sealed photometric plan	12/09/2025 1:36	PMFile Category Placeholder.pdf	16
Susan Heyen	1. Landscape Plans to be signed and sealed per 6.2.1.2. Please submit signed and sealed Irrigation plans	12/09/2025 1:37	PMFile Category Placeholder.pdf	16

OCE: Plan Review (DR) v.3

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
911 Management (DR) (911 Management)	Janet Warbach	02/12/2026	02/10/2026	Approved
Environmental Health (Plans) (Environmental Health)	Evan Searcy	02/12/2026	02/06/2026	Approved
Fire Marshal (Plans) (Fire)	Jonathan Kenning	02/12/2026	02/05/2026	Approved
<i>Comments</i>	Previously Approved			
Growth Services Planning & Zoning (DR) (GS Planning and Zoning)	Xinyi Chen	02/12/2026	02/06/2026	Approved
<i>Corrections</i>	4.4 - Show proposed signs to meet LDC Sec 4.4 (Resolved) - 4.4 - Show proposed signs to meet LDC Sec 4.4: If sign(s) is proposed on site, show proposed sign's location and design. The signs shall comply with LDC Sec. 4.4. A master sign plan and/or permit may be required.			
<i>Corrections</i>	6.5 & 6.6 - Habitat Preservation/Mitigation (Resolved) - 6.5 & 6.6 - Habitat Preservation/Mitigation: Refer to LDC Sec. 6.6 for requirements and design standards if the site contains open water, wetland, listed species, native habitat vegetation, and/or natural open space. When a proposed development or land clearing site is found to include listed species, the application shall identify species and habitat protection as on-site or off-site. The selected option shall be a condition of approval and shall be completed at time of final inspection.			
<i>Corrections</i>	2.12.27 - Location & screening of outside storage (Resolved) - 2.12.27 - Location & screening of outside storage: Provide a statement indicating any outside storage area is proposed. If applicable, show location of outside storage areas on plan. Check special requirements under zoning code sections.			
Landscape (Plans) (Parks and Recreation)	Susan Heyen	02/12/2026	02/09/2026	Approved
OCE Design (Plans) (Office of the County Engineer)	Gerald Koch	02/12/2026	02/20/2026	Approved
<i>Corrections</i>	2.12.3 - Title block (Resolved) - 2.12.3 - Title block: Title block on all sheets denoting type of application; project name, location, county, and state; and date of original and all revisions			
<i>Corrections</i>	2.12.4.I & 6.2.1.D - Index of sheets and numbering (Resolved) - 2.12.4.I & 6.2.1.D - Index of sheets and numbering: Index of sheets; All sheets shall indicate each sheet number and the total number of sheets. Cross references between sheets is required			
<i>Corrections</i>	2.18.2.G Utility Easements (Resolved) - 2.18.2.G Utility Easements: Easement requirements of each utility shall be indicated by the utility on a copy of the Preliminary Plat or by letter. (Letters/emails of easement acceptance due with improvement plan.)			
<i>Corrections</i>	Legal Documents (Resolved) - Legal Documents			
<i>Corrections</i>	2.21.2.A - Multi-phase Major Site Plans (Resolved) - 2.21.2.A - Multi-phase Major Site Plans: Multi-phase Major Site Plans may include a separate sheet showing independent, stand alone phasing and shall not be subject to a separate Master Plan application			
<i>Corrections</i>	6.2.1.A. - Licensed Professional (Resolved) - 6.2.1.A. - Licensed Professional: Plans shall be prepared by a professional licensed by the State of Florida. The name, street address, signature, date, license number, and seal of the responsible professional shall be shown on each plan sheet. The same shall be provided on the cover page of any supporting documents and calculations.			
<i>Corrections</i>	2.12.4.E & 6.2.1.A - Licensed Professional (Resolved) - 2.12.4.E & 6.2.1.A - Licensed Professional: 2.12.4.E & 6.2.1.A - The name, address, phone number, signature, date, license number, and seal of the responsible professional shall be shown on each plan sheet			
<i>Corrections</i>	6.2.1.B.-F. - Requirements (Resolved) - 6.2.1.B.-F. - Requirements: Technical standards and requirements as listed in Section 6.2.1.B. through F. of the LDC			
<i>Corrections</i>	Additional Design Comments (Resolved) - Additional Comments:			
<i>Corrections</i>	2.12.4 - Front page of the plan (Resolved) - 2.12.4 - Front page of the plan: Front page of the plan shall minimally include A through L of this section of the LDC.			
<i>Corrections</i>	2.21.2.A - Multi-phase Major Site Plans (Resolved) - 2.21.2.A - Multi-phase Major Site Plans: Multi-phase Major Site Plans may include a separate sheet showing independent, stand alone phasing and shall not be subject to a separate Master Plan application			

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
OCE Property Management (Plans) (Office of the County Engineer) <i>Comments</i>	Elizabeth Woods	02/12/2026	02/17/2026	Informational
<p>Sunbiz and Project map checked -EMW 9.4.25</p> <p>IF APPLICABLE:</p> <p>Sec. 2.18.1.I - Show connections to other phases.</p> <p>Sec.2.19.2.H – Legal Documents</p> <p>Legal documents such as Declaration of Covenants and Restrictions, By-Laws, Articles of Incorporation, ordinances, resolutions, etc.</p> <p>Sec. 6.3.1.B.1 – Required Right of Way Dedication (select as appropriate)</p> <p>For Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated for the use and benefit of the public."</p> <p>Sec. 6.3.1.B.2 – Required Right of Way Dedication</p> <p>For Non-Public Streets. "[All streets and rights-of-way shown on this plat or name specifically if less than all] are hereby dedicated privately to the [entity name]. All public authorities and their personnel providing services to the subdivision are granted an easement for access. The Board of County Commissioners of Marion County, Florida, shall have no responsibility, duty, or liability whatsoever regarding such streets. Marion County is granted an easement for emergency maintenance in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk."</p> <p>Sec. 6.3.1.D.3 - Cross Access Easements</p> <p>For Cross Access Easements. "All parallel access easements shown on this plat are hereby dedicated for the use and benefit of the public, and maintenance of said easements is the responsibility of [entity name]."</p> <p>Sec. 6.3.1.C.1 - Utility Easements (select as appropriate)</p> <p>"[All utility easements shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction, installation, maintenance, and operation of utilities by any utility provider."</p> <p>Sec. 6.3.1.C.2 – Utility Easements</p> <p>"[All utility tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities."</p> <p>Sec.6.3.1.D(c)(1)(2)(3) - Stormwater easements and facilities, select as appropriate:</p> <ol style="list-style-type: none"> "[All stormwater and drainage easements as shown or noted or name specifically if less than all] are dedicated [private or to the public] for the construction and maintenance of such facilities." "[All stormwater management tracts or identify each tract as appropriate] as shown are dedicated [private or to the public] for the construction and maintenance of such facilities." When any stormwater easement and/or management tract is not dedicated to the public or Marion County directly, the following statement shall be added to the dedication language: "Marion County is granted the right to perform emergency maintenance on the [stormwater easement and/or management tract, complete accordingly] in the event of a local, state, or federal state of emergency wherein the declaration includes this subdivision or an emergency wherein the health, safety, or welfare of the public is deemed to be at risk." <p>Sec.6.3.1.D(f) –</p> <p>If a Conservation Easement is required the following shall be provided: "A conservation easement [as shown or on tract and identify the tract, complete accordingly] is dedicated to [the Board of County Commissioners of Marion County, Florida or entity name, if not Marion County] for the purpose of preservation of [listed species, habitat, Karst feature and/or native vegetation, complete accordingly]."</p>				
OCE Stormwater (Permits & Plans) (Office of the County Engineer) <i>Recommendations</i>	Kevin Vickers	02/12/2026	02/09/2026	Approved
<p>Copy of District Permit (County Interest) - Please provide a copy of the District permit prior to construction.</p> <p>6.13.10.B <input type="checkbox"/> Copy of NPDES Permit or NOI - Please provide a copy of the NPDES permit or NOI prior to construction.</p> <p>Additional Stormwater comments - If you have questions or would like to discuss the stormwater review comments, please contact Kevin Vickers, PE at 352-671-8695 or kevin.vickers@marionfl.org.</p>				
OCE Survey (Plans) (Office of the County Engineer)	Theresa Smail	02/12/2026	02/10/2026	Approved
OCE Traffic (Permits & Plans) (Office of the County Engineer)	Chris Zeigler	02/12/2026	02/05/2026	Approved

SUBMITTAL SUMMARY REPORT (33189)

ITEM REVIEW NAME (DEPARTMENT)	ASSIGNED TO	DUE	COMPLETE	STATUS
Utilities (OCE Plans) (Utilities)	Heather Proctor	02/12/2026	02/09/2026	Approved
<i>Comments</i>	Previously approved by Marion County Utilities (MCU) staff. The project will connect to Phase I of the storage facility, which is currently served by MCU public water and sewer.			
<i>Recommendations</i>	Sheet 05.01 - Fix leader showing (2) 8" - 45" BENDS - Its pointed at the proposed fire hydrant currently.			



MARRION COUNTY APPROVAL STAMP

THOMAS & ASSOCIATES ENGINEERING, LLC
 CIVIL ENGINEERING - PLANNING - LANDSCAPE ARCHITECTURE - SURVEYING
 1720 SE 18TH AVE, SUITE 100, OCEAN FL 33471
 PHONE: 561-966-1111 FAX: 561-966-1115
 WWW: WWW.THOMASANDASSOCIATES.COM

REVISIONS	
DATE	


AERIAL PHOTOGRAPH

PROJECT: SW 8TH AVENUE RESIDENTIAL PHASE 2
 LOCATION: MARRION COUNTY, FLORIDA

DATE: 11/05/2021	
DRAWN BY: JS	
CHECK BY: JL	
JOB NO: 21-006	

SHEET: 03.01


NOT VALID UNLESS SIGNED AND SEALED BY A PROFESSIONAL ENGINEER



NOT VALID UNLESS SIGNED AND SEALED BY A PROFESSIONAL ENGINEER

Thomas C. Associates
ENGINEERING, L.L.C.
 CIVIL ENGINEERING - PLANNING - LANDSCAPE ARCHITECTURE - ENVIRONMENTAL
 1720 SE 18th Ave. #609, Doral, FL 33171
 OFFICE: (305) 253-4565
 CELL: (305) 253-4566
 CONTRACT NO. 23-5004 (PHASE 2)

MARRION COUNTY APPROVAL STAMP



- GRADING LEGEND**
- EXISTING CONTOURS
 - PROPOSED CONTOURS
 - PROPOSED STORM PIPE
 - PROPOSED SWALE BOTTOM
 - PROPOSED STRUCTURE ID
 - GATE INLET


NOTES

- PLEASE REFER TO POST DEVELOPMENT BASIN MAP IN SUBMITTALS REPORT FOR DETAILS OF POST BASIN.

MAJOR SITE PLAN - STORAGE PHASE 2
 MARRION COUNTY, FLORIDA
MASTER DRAINAGE PLAN

DATE: 11/2/2023
 DRAWN BY: AS
 CHKD BY: JL
 JOB NO.: 23-5004

SHEET: 04.01



NOT VALID UNLESS SIGNED AND SEALED BY A PROFESSIONAL ENGINEER

3/20/2023 10:58 AM C:\Users\jason\OneDrive\Documents\Projects\23-0060\23-0060.dwg 1/21/2023 10:58 AM














Thomas C. Armstrong, P.E.
ENGINEERING, LLC
1720 SE 8th Ave Bldg 100, Ocala, FL 34471
352.237.1234
TCA@TCAENGINEERING.COM

REVISIONS:	
DATE:	

MARRON COUNTY STORAGE PHASE 2
MARRON COUNTY, FLORIDA
GRADING AND DRAINAGE PLAN

DATE: 11/2/2023
DRAWN BY: JS
CHECK BY: JH
JOB NO.: 23-0060

SHEET: 07.01



NOT VALID UNLESS SIGNED AND SEALED BY A PROFESSIONAL ENGINEER

Small text at the bottom left of the page.

THOMAS & ASSOCIATES ENGINEERING, LLC
 1720 DE SOTO AVE. SUITE 100, OMAHA, NE 68101
 (402) 426-1234
 FAX: (402) 426-1235
 WWW.THOMASANDASSOCIATES.COM

MARION COUNTY APPROVAL STAMP







--	--	--	--	--	--	--	--	--	--

REGISTRATION NO. 111111
 EXPIRES 12/31/2024
 PROJECT NO. 22-0001
 SHEET NO. 08.01

DATE: 11/15/2023
 DRAWN BY: AS
 CHECK BY: TB
 JOB NO.: 22-0001

THOMAS & ASSOCIATES ENGINEERING, LLC
 1720 DE SOTO AVE. SUITE 100, OMAHA, NE 68101
 (402) 426-1234
 FAX: (402) 426-1235
 WWW.THOMASANDASSOCIATES.COM

WATER DISTRIBUTION DETAILS



MARION COUNTY APPROVAL STAMP

THOMAS & ASSOCIATES, INC.
ENGINEERING, LLC
1720 SE 8th Ave Bldg 100, Ocala, FL 34471
ORANGE COUNTY, FL 32137
TEL: 352.237.4475
FAX: 352.237.4476



REVISIONS	
DATE	

W. JAMES SMITH, P.E.
REGISTERED PROFESSIONAL ENGINEER
MARION COUNTY, FLORIDA

SANITARY SEWER DETAILS

DATE: 11/2/2011
DRAWN BY: AS
CHECKED BY: JH
JOB NO: 11-066

DATE: 11/2/2011
DRAWN BY: AS
CHECKED BY: JH
JOB NO: 11-066



DATE	REVISION	BY	CHKD

CONCRETE PAVEMENT SECTION

DATE	REVISION	BY	CHKD

HEAVY DUTY PAVEMENT SECTION

ALL CONSTRUCTION COVERED BY THESE PLANS SHALL COMPLY WITH MATERIAL REQUIREMENTS AND QUALITY CONTROL STANDARDS CONTAINED IN THE MARION COUNTY LDC.

- NOTES:
1. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL OBTAIN FROM THE ENGINEER OR OWNER A COPY OF ALL REVISIONS RELATING TO THIS PROJECT. IT IS THE CONTRACTOR'S RESPONSIBILITY TO ASSURE THAT ALL CONSTRUCTION ACTIVITIES ARE IN CONFORMANCE WITH THE CONDITIONS OF ALL REVISIONS AND APPROVALS.
 2. GRADES AND MATCH OR SOLID SOILS: ALL AREAS IN EXISTING RIGHTS-OF-WAY DISTURBED BY CONSTRUCTION.
 3. CONTRACTOR IS TO CONDUCT ALL WORK WITHIN, BUT NOT LIMITED TO, THE CITY OF BELLFLOW RIGHTS-OF-WAY WITH UTILITY COMPANIES IN ORDER TO PREVENT DAMAGE TO CITY UTILITY AND THE BARRING OF ADJACENT'S UTILITY & RIGHTS.
 4. CONTRACTOR SHALL CONTACT THE ENGINEER AND/OR THE OWNER PRIOR TO ANY CONSTRUCTION THAT MAY DAMAGE TREES.
 5. EXISTING MARKING AND SIGNAGE CONFORM TO THE LATEST EDITION OF THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES AND THE FOOT DESIGN STANDARD AS APPLICABLE.



Thomas & Associates, LLC
ENGINEERING, LLC
 ONE HUNDRED-SEVEN HUNTER-LEITCH AVENUE - BOWENHILL
 1720 SE 18TH AVE. BOYD, FLORIDA, 32407
 PHONE: 904.226.3333
 FAX: 904.226.3345
 WWW.TANDASSOCIATES.COM

DATE	REVISION	BY	CHKD

THOMAS & ASSOCIATES, LLC
 ENGINEERING, LLC
 MARION COUNTY, FLORIDA
ROADWAY & PAVEMENT
DETAILS

DATE: 11/2/2021
 DRAWN BY: AS
 CHECKED BY: JL
 JOB NO.: 21-0160

sheet 10.01




EROSION CONTROL LEGEND
 PROPOSED SILT FENCE

GENERAL NOTES

1. THE FOLLOWING LIST REPRESENTS A BASIC EROSION AND SEDIMENT CONTROL PROGRAM WHICH IS TO BE IMPLEMENTED TO HELP PREVENT OFF SITE SEDIMENTATION DURING AND AFTER CONSTRUCTION OF THE PROJECT.
2. TEMPORARY EROSION CONTROL TO BE UTILIZED DURING CONSTRUCTION AT AREAS DESIGNATED BY THE ENGINEER OR AREAS ON SITE WHERE UNSTABILIZED GRADES MAY CAUSE EROSION PROBLEMS. EROSION CONTROL MAY BE REMOVED AFTER STABILIZATION AREA HAS BEEN ESTABLISHED BY VEGETATION OR COMPLETED AS DETERMINED BY THE OWNER.
3. PERMANENT EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AT THE EARLIEST PRACTICAL TIME CONSISTENT WITH GOOD CONSTRUCTION PRACTICES. ONE OF THE FIRST CONSTRUCTION ACTIVITIES SHOULD BE THE PLACEMENT OF PERMANENT AND TEMPORARY EROSION AND SEDIMENT CONTROL MEASURES AROUND THE PERIMETER OF THE PROJECT OR THE AREAS TO BE PROTECTED BY THE PROJECT. ADJACENT PROPERTIES AND WATER BODIES.
4. TEMPORARY EROSION AND SEDIMENT CONTROL MEASURES SHALL BE COORDINATED WITH PERMANENT MEASURES TO ACHIEVE ECONOMICAL, EFFECTIVE AND CONTINUOUS CONTROL THROUGHOUT THE CONSTRUCTION PHASE. TEMPORARY MEASURES SHALL NOT BE CONSIDERED FOR EXTENDED PERIODS OF PERMANENT MEASURES.
5. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE ADEQUATELY MAINTAINED TO PERFORM THEIR INTENDED FUNCTION DURING CONSTRUCTION OF THE PROJECT.
6. NECESSARY REPAIRS TO BARRIERS OR REPLACEMENT OF BARRIERS SHALL BE ACCOMPLISHED PROMPTLY.
7. SEDIMENT TRAP(S) SHALL BE REMOVED AFTER EACH RAINFALL. THE TRAP(S) SHALL BE REMOVED WHEN THE LEVEL OF SEDIMENT REACHES APPROXIMATELY ONE HALF THE HEIGHT OF THE BARRIERS OR HIGH WATER.
8. MATERIAL FROM SEDIMENT TRAPS SHALL NOT BE STOCKPILED OR DISPOSED OF IN A MANNER WHICH MAKES THEM READILY SUSCEPTIBLE TO BEING WASHED INTO ANY WATERCOURSE BY RUNOFF OR HIGH WINDS.
9. ANY SEDIMENT DEPOSITS REMAINING IN PLACE AFTER THE BARRIERS SHALL BE DESIGNED TO CONFORM TO THE EXISTING GRACE, PREPARED AND SEEDED.
10. SILT FENCE TO BE PAID FOR UNDER THE CONTRACT UNIT PRICE FOR STAIRED SILT FENCE (U).
11. ALL INLETS TO BE PROTECTED BY DETAILS AS OUTLINED IN F.D.O.T. EROSION SEDIMENT CONTROL MANUAL (LATEST EDITION).
12. CONTRACTOR MUST MAINTAIN POSITIVE DRAINAGE AT ALL TIMES DURING THE COURSE OF THE CONSTRUCTION WORK.
13. CONTRACTOR SHALL COORDINATE WITH ALL OF THE RESPONSIBLE AGENCIES PERTAINING TO EROSION AND SEDIMENT CONTROL WORK AND MAKE NECESSARY CHANGES BASED ON THE AGENCY'S GUIDANCE/DIRECTION AT NO ADDITIONAL COST TO THE OWNER.
14. THE EROSION CONTROL MEASURES SHOWN ON THIS PLAN ARE, AT THE DISCRETION OF THE ENGINEER, THE MINIMUM THAT MAY BE REQUIRED. ACTUAL FIELD CONDITIONS MAY REQUIRE OTHER ADDITIONAL OR REDUCED EROSION CONTROL MEASURES TO BE IMPLEMENTED. THE CONTRACTOR IS DIRECTED TO FOLLOW STANDARD BEST MANAGEMENT PRACTICES IN IMPLEMENTING THE SUCCESSFUL EROSION CONTROL PLAN.
15. ALL DISTURBED AREAS TO BE SOLOED OR SEEDED AND MULCHED WITHIN 7 DAYS AFTER FINAL GRADING.

MARION COUNTY APPROVAL STAMP



THOMAS & ASSOCIATES, INC.
ENGINEERING, LLC
 CIVIL ENGINEERING - PLANNING - LANDSCAPE ARCHITECTURE - ENVIRONMENTAL
 1720 SE 18TH AVENUE, SUITE 100, OCOEE, FL 32971
 PHONE: 407-831-7475
 FAX: 407-831-7475
 EMAIL: INFO@THOMASANDASSOCIATES.COM

MARION COUNTY APPROVAL STAMP


DATE: 11/05/2021
 DRAWN BY: AS
 CHECKED BY: JL
 JOB NO.: 21-0960

PROJECT: MARION COUNTY STORAGE PHASE 2
 MARION COUNTY, FLORIDA


EROSION CONTROL PLAN

SHEET: 12.01


NOT VALID UNLESS SIGNED AND SEALED BY A PROFESSIONAL ENGINEER



MULTI-STEM TREE PLANTING
NOT TO SCALE



SINGLE-TRUNK TREE PLANTING (8\"/>




TREE PLANTING (2\"/>


STAKING NOTES:

CONTRACTOR SHALL PROVIDE TO THE LANDSCAPE ARCHITECT AND INCLUDE IN BID MATERIAL AN ATTACHED STAKING SPECIFICATION FOR LARGE TREES:


TREE FRONTS (FRONT AND REAR) SHALL BE PROTECTED BY 2\"/>




SOD PLACEMENT ADJACENT TO PAVEMENT
NOT TO SCALE



SCREEN DETAIL: TRANSFORMERS/WELLS/UTILITIES
NOT TO SCALE



PLANT OFFSET SCENARIOS
NOT TO SCALE



SHRUBS AND GROUNDCOVER PLANTING
NOT TO SCALE

MARION COUNTY APPROVAL STAMP

Thomas C. Anderson
ENGINEERING, LLC
1000 S.W. 10TH AVENUE, SUITE 100
GAINESVILLE, FL 32601
OFFICE: (352) 387-4590 FAX: (352) 387-4595

DATE	1/11/2024
BY	SM
CHECKED BY	SM
DATE	2/1/2024

MAJOR SITE PLAN
NEIGHBORHOOD STORAGE PHASE 2
MARION COUNTY, FLORIDA

PLANTING DETAILS

SUBMITTAL #1

shr_L05.01

NOT VALID UNLESS SIGNED AND SEALED BY AUTHORIZED PROFESSIONAL