## Sec. 6.13.4. Stormwater quantity criteria.

- A. Methodologies, rainfall distribution and intensities shall be consistent with those approved by the governing water management district. Assumed parameters must be supported by conventional methods.
- B. Design storms shall consider open or closed basins as provided in Table 6.13-1.

Basin	Frequency	Peak Discharge Rate	Discharge Volume
	Duration		
Open Basin	25-year 24-hour	Post 25-year and 100-	Post 25-year and 100-
	and	year less than or equal to	year less than or equal to
	100-year 24-hour	pre-developed conditions	pre-developed conditions
			during 24-hour storm <sup>2</sup>
Closed Basin	25-year 24-hour	Post 25-year and 100-	Post 25-year and 100-
	and	year less than or equal to	year less than or equal to
	100-year 24-hour	pre-developed conditions	pre-developed conditions
			during 24-hour storm and
			following 14-day period <sup>2</sup>
Open Basin subject to	25-year 24-hour	Post 25-year and 100-	Post 25-year and 100-
downstream flooding <sup>1</sup>	and	year at least 25 percent	year less than or equal to
	100-year 24-hour	less than pre-developed	pre-developed conditions
		conditions	during 24-hour storm
Closed Basin subject	25-year 24-hour	Post 25-year and 100-	Post 25-year and 100-
to downstream	and	year less than or equal to	year at least 25 percent
flooding <sup>1</sup>	100-year 24-hour	pre-developed conditions	less than pre-developed
			conditions during 24-hour
			storm and following 14-
			day period

 Table 6.13-1 Design Storms and Discharge Conditions

<sup>1</sup> Downstream flooding is that flooding of structures or hindering of access which has been validated by the County Engineer or their designee through field observations.

<sup>2</sup> An overage tolerance no greater than half the pre-developed volume of the 2-year 24-hour storm is permitted upon approval by the County Engineer or their designee.

- C. Discharge conditions
  - (1) All stormwater facilities shall be designed to limit discharges considering open or closed basins per Table 6.13-1.
  - (2) Discharges shall mimic the pre-development condition, match the pre-development location and not exceed the pre-development rate, except when discharging into a stormwater system designed to accept such discharges.
  - (3) The bypass or discharge of offsite runoff, shall be allowed when it mimics the pre-development condition, matches the pre-development location and does not exceed the pre-development rate, except when discharging into a stormwater system designed to accept such discharges.
  - (4) In closed basins with downstream flooding, existing improvements may be excluded from the discharge volume reduction requirements when all of the following apply:

(Supp. No. 5)

- (a) The existing improvements were constructed as part of a development with a permitted stormwater system or constructed prior to stormwater permitting requirements and
- (b) Discharge from the existing improvements is into a system designed to accept such discharges.
- (5) A discharge structure shall be required for all stormwater facilities not designed to retain the entire post-development design storm.
- (6) Discharge structures shall include a skimmer at a minimum. Design elements such as baffles or other mechanisms suitable for preventing oils, greases, and floating pollutants from discharging out of the facility shall be considered. When discharging from a natural facility, a skimmer may not be required upon approval from the County Engineer or their designee. When a grassed weir is used it shall be armored or constructed with a concrete center to resist erosion and withstand the anticipated flow velocity.
- D. Recovery.
  - (1) All stormwater facilities in closed basins shall recover the total volume required to meet the discharge volume limitations within 14 days following the design rainfall event.
  - (2) For stormwater facilities not able to recover the total required volume within 14 days, the stormwater facility volume shall be increased to retain an additional volume of the post minus pre difference in runoff for 100-year 24-hour design storm. The control elevation for retaining this volume shall be no greater than the top of constructed stormwater facility or the easement limits of a natural facility. Credit for the recovered volume through the 14-day duration may be considered to meet this requirement.
  - (3) All stormwater facilities in open basins shall have adequate storage volume available to meet the peak discharge requirements within 72 hours following the design rainfall event. The control elevation for this storage volume shall be no greater than the top of constructed stormwater facility or easement limits of a natural facility. The total post minus pre difference in runoff volume shall not be released in less than 24 hours following the design rainfall event.
- E. Infiltration or percolation can be considered when establishing the design high and discharge elevation.
- F. Other design criteria may be used if approved by the County Engineer or their designee.

(Ord. No. 13-20, § 2, 7-11-2013)