

June 28, 2024

PROJECT NAME: JANCINTO GARCIA

PROJECT NUMBER: 2024060049

APPLICATION: DRC WAIVER REQUEST #31689

- 1 DEPARTMENT: FRMSH - FIRE MARSHAL REVIEW
REVIEW ITEM: LDC 2.21.1.A(1) Major Site Plan
STATUS OF REVIEW: INFO
REMARKS: Approved
- 2 DEPARTMENT: LUCURR - LAND USE CURRENT REVIEW
REVIEW ITEM: LDC 2.21.1.A(1) Major Site Plan
STATUS OF REVIEW: INFO
REMARKS: Defer to stormwater, no concerns.
- 3 DEPARTMENT: ZONE - ZONING DEPARTMENT
REVIEW ITEM: LDC 2.21.1.A(1) Major Site Plan
STATUS OF REVIEW: INFO
REMARKS: DEFER TO STORMWATER
ZONING SUPPORTS THE REQUEST PROVIDED ALL REQUIRED SETBACKS ARE MET.
ACREAGE: 0.24
FLU: HR
ZONING: R-1
- 4 DEPARTMENT: UTIL - MARION COUNTY UTILITIES
REVIEW ITEM: LDC 2.21.1.A(1) Major Site Plan
STATUS OF REVIEW: INFO
REMARKS: APPROVED - MCU service area but outside connection distance to closest water or sewer mains at this time. Shall connect within 365 days' notice of availability.
- 5 DEPARTMENT: ENGDRN - STORMWATER REVIEW
REVIEW ITEM: LDC 2.21.1.A(1) Major Site Plan
STATUS OF REVIEW: INFO
REMARKS: CONDITIONAL APPROVAL subject to working with Stormwater staff under the following conditions: 1) The applicant must provide stormwater control of the additional runoff from the impervious coverage at the 100-year, 24-hour storm from the proposed project. 2) A permit/inspection hold will be in effect until a sketch of the proposed stormwater controls is provided to Stormwater and approved. 3) A Final Hold will be in effect until: a) Stormwater staff conducts a final inspection. Please note that stormwater controls and all disturbed areas must have vegetative cover established at time of final inspection. b) The applicant must provide a final sketch, noting the horizontal extents and volume capacity of the stormwater controls.
The applicant owns a 0.24 -acre parcel (9016-0244-27) and according to the MCPA, there is approximately 3,750 sf existing impervious area on-site. The applicant is proposing to add 200 sf for a carport. The total existing and proposed impervious area is 3,950 sf. The site will be approximately 291 sf over the allowed 35% (3,659 sf) per the Marion County LDC. There is no FEMA Special Flood Hazard Areas or Flood Prone Areas on the property. Staff recommends approval with conditions.



**Marion County
Board of County Commissioners**

AR# 31689

Office of the County Engineer

412 SE 25th Ave.
Ocala, FL 34471
Phone: 352-671-8686
Fax: 352-671-8687

DEVELOPMENT REVIEW COMMITTEE WAIVER REQUEST FORM

Date: 06/19/2024 Parcel Number(s): 9016-0244-27 Permit Number: _____

A. PROJECT INFORMATION: Fill in below as applicable:

Project Name: Jacinto Garcia Commercial Residential
Subdivision Name (if applicable): _____
Unit _____ Block _____ Lot _____ Tract _____

B. PROPERTY OWNER'S AUTHORIZATION: The property owner's signature authorizes the applicant to act on the owner's behalf for this waiver request. The signature may be obtained by email, fax, scan, a letter from the property owner, or original signature below.

Name (print): Jacinto Garcia
Signature: Jacinto Garcia
Mailing Address: 7 Bahia Pass Loop City: Ocala
State: Florida Zip Code: 34472 Phone #: (296) 868 2411
Email address: Jacymel7@hotmail.com

C. APPLICANT INFORMATION: The applicant will be the point of contact during this waiver process and will receive all correspondence.

Firm Name (if applicable): SAME AS ABOVE Contact Name: _____
Mailing Address: _____ City: _____
State: _____ Zip Code: _____ Phone #: _____
Email address: _____

D. WAIVER INFORMATION:

Section & Title of Code (be specific): _____ 2.21.1.A Major Site Plan
Reason/Justification for Request (be specific): _____
10x20 CARPORT

DEVELOPMENT REVIEW USE:

Received By: _____ Date Processed: 06/24/2024 Project # 2024060049 AR# 31689

ZONING USE: Parcel of record: Yes No Eligible to apply for Family Division: Yes No
Zoned: _____ ESOZ: _____ P.O.M. _____ Land Use: _____ Plat Vacation Required: Yes No
Date Reviewed: _____ Verified by (print & initial): _____



R1/HR

max imp.
curr.
prop:

3659sf
3750sf

$\frac{200}{3950sf.}$

Stormwater Dept

352-671-8686

loading...

