

# SUBMITTAL SUMMARY REPORT (33549)

**ITEM REVIEW NAME (DEPARTMENT)**

OCE Stormwater (Permits & Plans) (Office of the County Engineer)

**ASSIGNED TO**

Alexander Turnipseed

**DUe**

01/14/2026

**COMPLETE**

01/05/2026

**STATUS**

Informational

**Comments**

Applicant has provided a signed and sealed drainage memo identifying a de minimus impact on the existing drainage system.

OCE Traffic (Permits & Plans) (Office of the County Engineer)

01/14/2026

01/05/2026

Approved

OCE Utilities (Plans) (Utilities)

Heather Proctor

01/14/2026

01/13/2026

Approved

**Comments**

APPROVED - MCU has no comment on this waiver. Parcel 41200-060-02 is within the Marion County Utilities service area and will connect to both water and sewer. The waiver for applicability and parking spaces has no impact on water or sewer flows.

This parcel is located outside both the Urban Growth Boundary and the Primary Springs Protection Zone.

---