



roadway width approx 150 LF

16 inch water main currently under construction by MCU

minimum 440 LF of sewer force main extension required by developer based on project ERCs

At the proposed 40 seats, under 16 hours per day, with only disposable goods, projected flows by LDC Table 6.14-1 calculate to 800 gpd of water and wastewater - this equals

2.0 water ERCs with a connection distance of 800 LF
4.0 sewer ERCs with a connection distance of 1,600 LF

Both connection distances (by developer extension) are tripped, and required as part of the Major Site Plan (AR 29286)

220 LF frontage

80 LF frontage

1470-001-017

1470-001-019

1470-001-022

1470-001-023

1470-001-024

465 LF combined frontage

550 LF off-site water main extension required by developer based on project ERCs